



**SLOVENSKA
AKREDITACIJA**
SIST EN ISO/IEC 17065
CP-002

ZAG

**ZAVOD ZA
GRADBENIŠTVO
SLOVENIJE**

SLOVENIAN
NATIONAL BUILDING
AND CIVIL ENGINEERING
INSTITUTE

Dimičeva ulica 12
1000 Ljubljana
Slovenija

info@zag.si
www.zag.si

Notified certification body
NB 1404

Certificate of constancy of performance

1404 – CPR – 3055

(English translation, the original version is in Slovenian)

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction products Regulation or CPR), this certificate applies to the construction product

Insu-Rope

placed on the market under the name or trade mark of

**EZS d.o.o., Grosuplje,
Brezje pri Grosupljem 10, 1290 Grosuplje, Slovenia**

and produced in the manufacturing plant

Stična 1, 1295 Ivančna Gorica, Slovenia.

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in the

ETA-17/0061, issued on 24. 5. 2018

and

EAD 350141-00-1106

under system 1 for the performance set out in the ETA are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

constancy of performance of the construction product.

This certificate was first issued on **11. 10. 2018** and will remain valid until **22. 12. 2026** as long as neither the ETA, the EAD, the construction product, the AVCP method nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Detailed information about the scope of the product is given in the annex to this certificate.

Ljubljana, 22. 12. 2021



Authorised signatory of the Certification body:

Marjan Japelj, B. Sc.

Scope of the certificate:

Product	Description	Performance	Intended use
Insu-Rope	Rope from stone wool, diameter 12 – 180 mm	Reaction to fire: A1 Fire resistance: EI 240 * exact classification depending on the design is determined in ETA-17/0061, Annex B.	For sealing horizontal and vertical linear joints between fire resistant separating structural elements, gap width 10 to 150 mm

End of the Annex

