

Attestation

BREEAM®

On the 11th of April 2025 Eurofins Product Testing A/S received a sample of a sealant with the product name:

INTU FR GRAPHITE

supplied by

ALFASEAL GROUP Sp. z.o.o.

The sample was supplied as being representative of the manufactured product, and it has been tested as in accordance with the relevant EN 16516, ISO 16000-3, ISO 16000-6, ISO 16000-9, and ISO 16000-11 testing standards (See test report no.392-2025-00202303_A_EN).

The test results of the tested sample indicate that the product qualifies for the below mentioned BREEAM specifications on VOC emissions and by complying with:

- **BREEAM® International: Compliance with 'Exemplary' criteria on VOC emission** of BREEAM International: New Construction 2021, Technical Manual – SD250: Hea 02 Indoor Air Quality (version 6.0. of December 2021).
- **BREEAM® UK: Compliance with 'Exemplary' criteria on VOC emission** of BREEAM UK: New Construction 2024, Technical Manual - SD5079: Hea 02 Indoor Air Quality (version 6.1.2 of November 2024).
- **BREEAM® NL: Compliance with 'Exemplary' criteria on VOC emission** of BREEAM NL: Nieuwbouw en Renovatie Woningen 2023, Technical Manual: Hea 03 Gezonde binnenlucht (Version 1.01 of June 2023).
- **BREEAM® SE: Compliance with 'Exemplary' criteria on VOC emission** of BREEAM SE: New Construction 2023, Technical Manual: Hea 02 Indoor Air Quality (version 6.0. of January 2023).
- **BREEAM® NOR: Compliance with 'Exemplary' criteria on VOC emission** of BREEAM NOR: New Construction 2024, Technical Manual - SD5076NOR, Hea 02 Indoor Air Quality (version 6.1.1 of December 2024).

8 August 2025


Isabella B. Larsen
Analytical Service Manager
Janne Rothmann Norup
Analytical Service Manager