





Attestation

LEED v4, v4.1 BETA, and v5

On the 11th of April 2025 Eurofins Product Testing A/S received a sample of a sealant with the product name:

INTU FR GRAPHITE

supplied by

ALFASEAL GROUP Sp. z.o.o.

The sample was supplied as being representative of the manufactured product, and it has been tested in accordance with the relevant ISO 16000, EN 16516, and ASTM D2369 testing standards (See test report no. 392-2025-00202303 A EN and no. 392-2025-10202303 XG EN).

The test results of the tested sample indicate that the product qualifies for LEED v4, LEED v4.1 BETA (February 2025), and LEED v5 (April 2025) projects in Europe by showing compliance with the specifications for VOC emissions and VOC content by complying with:

VOC emissions specifications in LEED EQ credit "Low-Emitting Materials" for LEED projects in Europe:

- The requirements of LEED v4.1 BETA (February 2024) and LEED v5 (April 2025) by not exceeding the LCI values mentioned in the German AgBB Testing and Evaluation Scheme (2024), showing an overall R-value below or equal to 1 and having a TVOC according to EN 16516 below or equal to 1,000 μg/m³, a sum of VOC without LCI less than 100 μg/m³, and a formaldehyde emission below or equal to 10 μg/m³; all after 28 days.
- The requirements of LEED v4 by complying with:
 - o The requirements of Indoor Air Comfort Gold version 9.0 (June 2023).

VOC content specifications in LEED EQ credit "Low-Emitting Materials" for LEED projects in Europe:

 The requirements of LEED v4 and LEED v4.1 BETA (February 2025): South Coast Air Quality Management District (SCAQMD) Rule 1168 (2022) for 'All other sealants' having a VOC content below 250 g/L

15 September 2025

Isabella B. Larsen

Janne Rothmann Norup

LEED® is the preeminent program for the design, construction, maintenance and operations of high-performance green buildings. USGBC® and the related logo are trademarks owned by the U.S. Green Building Council and are used with permission.