

DECLARATION OF PRODUCER

No: DoP 3/2025

1. Unique identification code of product-type:
INTU FR GRILLE DS
2. Intended uses:
The intended use of INTU FR GRILLE DS is to reinstate the fire resistance performance of doors. Filling ventilation openings in fire resistance doors
3. Manufacturer:
**ALFASEAL GROUP Sp. z o.o.
ul. Kineskopowa 1, 05-500 Piaseczno**
4. Authorized representative:
Not applicable
5. System or systems of Assessment and Verification of Constancy of Performance (AVCP):
System 1
- 6a. Harmonised standard:
Not applicable
Notified body or bodies:
Not applicable
- 6b. European Assessment Document:
Not applicable
Technical Assessment:
No. 00518/25/Z00NZN
Technical Assessment Body:
ITB, ul. Filłrowa 1, 00-611 Warszawa
Notified body or bodies:
No. 1488
7. Declared performance:

Basic requirements	Performance characteristics
BWR 2 Safety in case to fire	
Reaction to fire	NPD
Resistance to fire	Max. EI 60 – According with Table 2 of Technical Assessment: No. 00518/25/Z00NZN
BWR 3 Hygiene, health and the environment	
Air permeability	NPD
Water permeability	NPD
Content, emission, release of dangerous substances	NPD
BWR 4 Safety and accessibility in use	
Mechanical resistance and stability	NPD
Resistance to impact/movement	NPD
Adhesion	NPD
Durability	Z ₂
BWR 5 Protection against noise	
Aireborne sound insulation	NPD
BWR 6 Energy economy and heat retention	
Thermal properties	NPD
Water vapour permeability	NPD

8. Appropriate technical documentation or special technical documentation:

Not applicable

The performance of the product identified above is in conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.


Signed for and on behalf of the manufacturer by:

Name: Michał Szykowski

Position: President of the Management Board

Piaseczno, 04.11.2025

Place, date



.....
Signature

Edition 2