



INSTYTUT TECHNIKI BUDOWLANEJ



Member of



www.eota.eu

European Technical Assessment

**ETA-24/1047
of 10/06/2026**



General Part

Technical Assessment Body issuing the European Technical Assessment

Instytut Techniki Budowlanej

Trade name of the construction product

INTU FR UNICOAT P
INTU FR UNIBOARD

Product family to which the construction product belongs

Fire Stopping and Fire Sealing Products.
Penetration Seals

Manufacturer

ALFASEAL GROUP Sp. z o.o.
ul. Kineskopowa 1
PL 05-500 Piaseczno, Poland

Manufacturing plant

Plant MPA1

This European Technical Assessment contains

65 pages including 3 Annexes which form an integral part of this Assessment

This European Technical Assessment is issued in accordance with Article 95(4) of Regulation (EU) 2024/3110, on the basis of

European Assessment Document (EAD)
350454-00-1104 "Fire Stopping and Fire Sealing Products. Penetration Seals"

This version replaces

ETA-24/1047 issued on 31/03/2026

Translations of this European Technical Assessment in other languages shall fully correspond to the original issued document and shall be identified as such.

Communication of this European Technical Assessment, including transmission by electronic means, shall be in full. However, partial reproduction may only be made with the written consent of the issuing Technical Assessment Body. Any partial reproduction has to be identified as such.

Specific Part

1 Technical description of the product

INTU FR UNICOAT P is an ablative paint used to form penetration seals where metal and combustible pipes and cables, single or in bundles, cable ladders, cable trays and conduits, penetrate walls and floors.

INTU FR UNIBOARD are mineral wool boards with nominal density of 140,0 kg/m³, pre-painted with paint INTU FR UNICOAT P – dry film thickness 0,5 mm:

- on one side – in case of INTU FR UNIBOARD 1S,
- on both sides – in case of INTU FR UNIBOARD 2S.

Auxiliary products used with INTU FR UNICOAT P and INTU FR UNIBOARD are:

- flexible elastomeric foam (FEF) Kaiflex ST insulation, produced by Kaimann company, according to EN 14304, with reaction to fire class B_L-s2, d0 according to EN 13501-1,
- polyethylene foam (PE) insulation Tubolit DG Plus insulation, produced by Armacell company, according to EN 14313, with reaction to fire class B_L-s1, d0 according to EN 13501-1,
- mineral wool Paroc Hvac Lamella Mat AluCoat mat produced by Paroc company, according to EN 14303, with a nominal density of 35 kg/m³ and reaction to fire class A1 according to EN 13501-1,
- rock mineral wool with a minimum density of 35 kg/m³ and reaction to fire class A1 according to EN 13501-1,
- INTU FR MASTIC according to ETA-19/0038,
- INTU FR GRAPHITE according to ETA-24/0152,
- INTU FR COLLAR L SLIM according to ETA-24/0497.

2 Specification of the intended use in accordance with the applicable European Assessment Document (EAD)

2.1 Intended use

The intended use of INTU FR UNICOAT P and INTU FR UNIBOARD is to reinstate the fire resistance performance of flexible wall, rigid wall or rigid floor constructions, where they are penetrated by metal pipes or combustible pipes, cables, cable ladders, cable trays and conduits.

The specific elements of construction that INTU FR UNICOAT P and INTU FR UNIBOARD may be used to provide a penetration seal in, are as follows:

- | | |
|-----------------|---|
| Rigid walls: | The wall must have a minimum thickness in accordance with Annex B, and comprise concrete or masonry separating elements, with a minimum density of 600 kg/m ³ in case of penetration seals given in Tables B1 to B4, B7, B9 to B11, B14, B16, B23 and B24 in Annex B or 450 kg/m ³ in case of penetration seals given in Tables B17, B19 and B21 in Annex B. |
| Flexible walls: | The wall must have a minimum thickness in accordance with Annex B, and comprise timber or steel studs lined on both faces with minimum two layers (with overall board layer thickness on one side equal to or greater than 25 mm) of type F or type DF gypsum plasterboards according to EN 520. In timber stud walls, no part of the penetration shall be closer than 100 mm to a stud, the cavity must be closed between the penetration seal and the stud and minimum 100 mm of insulation of reaction to fire class A1 or A2, according to EN 13501-1, is provided within the cavity between the penetration seal and the stud. |

Rigid floors: The floor must have a minimum thickness in accordance with Annex B, and comprise aerated concrete, concrete or reinforced concrete, with a minimum density of 550 kg/m³.

The supporting construction shall be classified in accordance with EN 13501-2 for the required fire resistance period (equal to or greater than specified in Annex B).

INTU FR UNICOAT P and INTU FR UNIBOARD may be used to provide a penetration seal with specific combustible and metal pipes and cables (according to Annex A and Annex B).

Details of penetration seals are provided in Annex B and Annex C. Distances between the services in the multiple penetration seals are given in Annex A. Additional provisions are provided in Annex A.

The provisions made in this European Technical Assessment are based on an assumed working life of the products of 25 years, when installed in the works, provided that the penetration seal is subject to appropriate installation, in accordance with the manufacturer's recommendations. The indications given on the working life cannot be interpreted as a guarantee given by the producer or the Technical Assessment Body, but are to be regarded only as a means for choosing the right products in relation to the expected economically reasonable working life of the works.

2.2 Use category

Type Z₂: intended for use in internal conditions with humidity lower than 85% RH, excluding temperatures below 0°C, without exposure to rain or UV.

3 Performance of the product and references to the methods used for its assessment

3.1 Performance of the product

3.1.1 Safety in case of fire (BWR 2)

Essential characteristic	Performance
Reaction to fire	No performance assessed
Resistance to fire	Annex C

3.1.2 Hygiene, health and the environment (BWR 3)

No performance assessed.

3.1.3 Safety and accessibility in use (BWR 4)

Essential characteristic	Performance
Mechanical resistance and stability	No performance assessed
Resistance to impact / movement	No performance assessed
Adhesion	No performance assessed
Durability	Use category: Type Z ₂

3.1.4 Protection against noise (BWR 5)

No performance assessed.

3.1.5 Energy economy and heat retention (BWR 6)

No performance assessed.

3.2 Methods used for the assessment

The assessment has been made in accordance with EAD 350454-00-1104.

4 Assessment and verification of constancy of performance (AVCP) system applied, with reference to its legal base

According to the Decision 1999/454/EC of the European Commission, as amended by Decision 2001/596/EC of the European Commission, the system 1 of assessment and verification of constancy of performance applies (see Annex V to Regulation (EU) 305/2011).

5 Technical details necessary for the implementation of the AVCP system, as provided in the applicable European Assessment Document (EAD)

Technical details necessary for the implementation of the AVCP system are laid down in the control plan deposited in Instytut Techniki Budowlanej.

For type testing the results of the tests performed as part of the assessment for the European Technical Assessment shall be used unless there are changes in the production line or plant. In such cases the necessary type testing has to be agreed between Instytut Techniki Budowlanej and the notified body.

Issued in Warsaw on 10/06/2026 by Instytut Techniki Budowlanej

Anna Panek, MSc
Deputy Director of ITB

Additional provisions

- INTU FR UNICOAT P ablative paint shall be painted on both sides of the wall or floor (for details see Annex C).
- Double INTU FR UNIBOARD 1S board and single INTU FR UNIBOARD 2S board in flexible or rigid wall and rigid floor supporting constructions are used for:
 - large penetration seals of cables,
 - multiple penetration seals of pipes.
- The penetration seals are made with use of double INTU FR UNIBOARD 1S board, thickness of 2 x 50 mm or 2 x 60 mm, placed flush with one or both of the supporting construction surfaces or inside the partition.
- The penetration seals are made with use of single INTU FR UNIBOARD 2S board, thickness of 1 x 50 mm or 1 x 60 mm, placed flush with one of the supporting construction surfaces or inside the partition.
- The following services can be used in large penetration seal of cables with double INTU FR UNIBOARD 1S board or single INTU FR UNIBOARD 2S board in flexible or rigid wall and rigid floor:
 - small cables ($\varnothing_{\text{cable}} \leq 21 \text{ mm}$),
 - medium cables ($21 \text{ mm} < \varnothing_{\text{cable}} \leq 50 \text{ mm}$),
 - large cables ($50 \text{ mm} < \varnothing_{\text{cable}} \leq 80 \text{ mm}$),
 - cable bundle ($\varnothing_{\text{bundle}} \leq 100 \text{ mm}$, $\varnothing_{\text{cable}} \leq 21 \text{ mm}$),
 - non-sheathed cables ($\varnothing_{\text{cable}} \leq 24 \text{ mm}$),
 - rigid plastic conduits ($\varnothing_{\text{conduit}} \leq 16 \text{ mm}$) – only in flexible or rigid wall.
- The following services can be used in multiple penetration seals:
 - pipes:
 - plastic pipe (without insulation) sealed with use of INTU FR COLLAR L SLIM collars (double-sided),
 - plastic pipe with PE insulation sealed with use of INTU FR COLLAR L SLIM collars (double-sided),
 - plastic pipe (without insulation) sealed with use of INTU FR GRAPHITE mass,
 - metal pipe (without insulation) sealed with INTU FR UNICOAT P paint,
 - metal pipe with mineral wool insulation (case LI and LS),
 - pipes with single INTU FR UNIBOARD 2S board in flexible or rigid wall:
 - plastic pipe (without insulation) sealed with use of INTU FR COLLAR L SLIM collars (double-sided),
 - metal pipe with mineral wool insulation,
 - pipes with double INTU FR UNIBOARD 1S board in rigid floor:
 - plastic pipe (without insulation) sealed with use of INTU FR COLLAR L SLIM collars (one-sided),
 - plastic pipe (without insulation) sealed with use of INTU FR GRAPHITE mass,
 - metal pipe (without insulation) sealed with INTU FR UNICOAT P paint,
 - metal pipe with mineral wool insulation (case LS),
 - pipes with single INTU FR UNIBOARD 2S board in rigid floor:
 - plastic pipe (without insulation) sealed with use of INTU FR COLLAR L SLIM collars (one-sided),
 - metal pipe with mineral wool insulation.
- The maximum dimensions (width x height) of penetration seals are:
 - in flexible or rigid wall made with use of double INTU FR UNIBOARD 1S board:
 - 1000 x 600 mm – in case of large penetration seal of cables,
 - 1000 x 600 mm – in case of horizontal orientation of multiple penetration seals of pipes,
 - 400 x 1000 mm – in case of vertical orientation of multiple penetration seals of pipes,
 - in flexible or rigid wall made with use of single INTU FR UNIBOARD 2S board:
 - 600 x 600 mm – in case of large penetration seal of cables,
 - 1000 x 600 mm – in case of multiple penetration seals of pipes,
 - in rigid floor made with use of double INTU FR UNIBOARD 1S board:
 - 1000 x 625 mm – in case of large penetration seal of cables,
 - 1200 x 625 mm – in case of horizontal orientation of multiple penetration seals of pipes,
 - in rigid floor made with use of single INTU FR UNIBOARD 2S board:
 - 625 x 1000 mm – in case of large penetration seal of cables,
 - 600 x 1200 mm – in case of multiple penetration seals of pipes.

INTU FR UNICOAT P, INTU FR UNIBOARD

Additional provisions (1)

Annex A
of European
Technical Assessment
ETA-24/1047

- The services in the multiple penetration seals of pipes with double INTU FR UNIBOARD 1S board or single INTU FR UNIBOARD 2S board are placed in the following distances (according to Figure A1 and Tables A1 to A4):
 - in rigid or flexible wall:
 - a_1 – distance between the pipe and the seal top edge (min. $a_1 = 20$ mm),
 - a_2 – distance between the pipe and the seal bottom edge (min. $a_2 = 70$ mm),
 - a_3 – distance between the pipe and the seal side edge (min. $a_3 = 20$ mm),
 - a_4 – distance between the adjacent penetration seals (min. $a_4 = 10$ mm),
 - in rigid floor:
 - a_1 – distance between the pipe and the short seal edge (min. $a_1 = 50$ mm),
 - a_3 – distance between the pipe and the long seal edge (min. $a_3 = 30$ mm),
 - a_4 – distance between the adjacent services ($a_4 = 100$ mm).




Fig. A1. Example of multiple penetration seal

Type of services:

- no. 1 – plastic pipe (without insulation) sealed with use of INTU FR COLLAR L SLIM collars
- no. 2 – plastic pipe with PE insulation sealed with use of INTU FR COLLAR L SLIM collars
- no. 3 – plastic pipe (without insulation) sealed with use of INTU FR GRAPHITE mass
- no. 4 – metal pipe (without insulation) sealed with INTU FR UNICOAT P paint
- no. 5 – metal pipe with mineral wool insulation

INTU FR UNICOAT P, INTU FR UNIBOARD

Additional provisions (2)

Annex A
of European
Technical Assessment
ETA-24/1047

Table A1. Minimum distances between the services in the multiple penetration seals of pipes made with use of single INTU FR UNIBOARD 2S board in flexible or rigid wall

Penetrating element	Top seal edge a_1	Bottom seal edge a_2	Side seal edge a_3	Type of adjacent service	a_4
Plastic pipe (without insulation) sealed with use of INTU FR COLLAR L SLIM collars (double-sided)	20 mm	70 mm	20 mm	Plastic pipe (without insulation) sealed with use of INTU FR COLLAR L SLIM collars (double-sided)	100 mm
				Metal pipe with mineral wool insulation	100 mm
Metal pipe with mineral wool insulation	20 mm	0 mm	0 mm	Metal pipe with mineral wool insulation	100 mm
				Plastic pipe (without insulation) sealed with use of INTU FR COLLAR L SLIM collars (double-sided)	100 mm

Table A2. Minimum distances between the services in the multiple penetration seals of pipes made with use of single INTU FR UNIBOARD 2S board in rigid floor

Penetrating element	Short seal edge a_1	Long seal edge a_3	Type of adjacent service	a_4
Plastic pipe (without insulation) sealed with use of INTU FR COLLAR L SLIM collars (one-sided)	50 mm	50 mm	Plastic pipe (without insulation) sealed with use of INTU FR COLLAR L SLIM collars (one-sided)	100 mm
			Metal pipe with mineral wool insulation	100 mm
Metal pipe with mineral wool insulation	50 mm	30 mm	Metal pipe with mineral wool insulation	100 mm
			Plastic pipe (without insulation) sealed with use of INTU FR COLLAR L SLIM collars (one-sided)	100 mm

INTU FR UNICOAT P, INTU FR UNIBOARD
Additional provisions (3)
Annex A
of European
Technical Assessment
ETA-24/1047

Table A3. Minimum distances between the services in the multiple penetration seals of pipes made with use of double INTU FR UNIBOARD 1S board in flexible or rigid wall

Penetrating element	Top seal edge a ₁	Bottom seal edge a ₂	Side seal edge a ₃	Type of adjacent service	a ₄
Plastic pipe (without insulation) sealed with use of INTU FR COLLAR L SLIM collars (double-sided)	20 mm	70 mm	50 mm	Plastic pipe (without insulation) sealed with use of INTU FR COLLAR L SLIM collars (double-sided)	100 mm
				Plastic pipe with PE insulation sealed with use of INTU FR COLLAR L SLIM collars (double-sided)	100 mm
				Plastic pipe (without insulation) sealed with use of INTU FR GRAPHITE mass	100 mm
				Metal pipe (without insulation) sealed with INTU FR UNICOAT P paint	100 mm
				Metal pipe with mineral wool insulation	100 mm
Plastic pipe with PE insulation sealed with use of INTU FR COLLAR L SLIM collars (double-sided)	30 mm	0 mm	30 mm	Plastic pipe with PE insulation sealed with use of INTU FR COLLAR L SLIM collars (double-sided)	100 mm
				Plastic pipe (without insulation) sealed with use of INTU FR COLLAR L SLIM collars (double-sided)	100 mm
				Plastic pipe (without insulation) sealed with use of INTU FR GRAPHITE mass	100 mm
				Metal pipe (without insulation) sealed with INTU FR UNICOAT P paint	100 mm
				Metal pipe with mineral wool insulation	100 mm
Plastic pipe (without insulation) sealed with use of INTU FR GRAPHITE mass	100 mm	10 mm	10 mm	Plastic pipe (without insulation) sealed with use of INTU FR GRAPHITE mass	10 mm
				Plastic pipe (without insulation) sealed with use of INTU FR COLLAR L SLIM collars (double-sided)	100 mm
				Plastic pipe with PE insulation sealed with use of INTU FR COLLAR L SLIM collars (double-sided)	100 mm
				Metal pipe (without insulation) sealed with INTU FR UNICOAT P paint	100 mm
				Metal pipe with mineral wool insulation	100 mm
Metal pipe (without insulation) sealed with INTU FR UNICOAT P paint	100 mm	100 mm	10 mm	Metal pipe (without insulation) sealed with INTU FR UNICOAT P paint	50 mm
				Plastic pipe (without insulation) sealed with use of INTU FR COLLAR L SLIM collars (double-sided)	100 mm
				Plastic pipe with PE insulation sealed with use of INTU FR COLLAR L SLIM collars (double-sided)	100 mm
				Plastic pipe (without insulation) sealed with use of INTU FR GRAPHITE mass	100 mm
				Metal pipe with mineral wool insulation	100 mm
Metal pipe with mineral wool insulation	100 mm	100 mm	0 mm	Metal pipe with mineral wool insulation	100 mm
				Plastic pipe (without insulation) sealed with use of INTU FR COLLAR L SLIM collars (double-sided)	100 mm
				Plastic pipe with PE insulation sealed with use of INTU FR COLLAR L SLIM collars (double-sided)	100 mm
				Plastic pipe (without insulation) sealed with use of INTU FR GRAPHITE mass	100 mm
				Metal pipe (without insulation) sealed with INTU FR UNICOAT P paint	100 mm
INTU FR UNICOAT P, INTU FR UNIBOARD					Annex A of European Technical Assessment ETA-24/1047
Additional provisions (4)					

Table A4. Minimum distances between the services in the multiple penetration seals of pipes made with use of double INTU FR UNIBOARD 1S board in rigid floor

Penetrating element	Short seal edge a_1	Long seal edge a_3	Type of adjacent service	a_4
Plastic pipe (without insulation) sealed with use of INTU FR COLLAR L SLIM collars (one-sided)	60 mm	50 mm	Plastic pipe (without insulation) sealed with use of INTU FR COLLAR L SLIM collars (double-sided)	100 mm
			Plastic pipe (without insulation) sealed with use of INTU FR GRAPHITE mass	100 mm
			Metal pipe (without insulation) sealed with INTU FR UNICOAT P paint	100 mm
			Metal pipe with mineral wool insulation	100 mm
Plastic pipe (without insulation) sealed with use of INTU FR GRAPHITE mass	100 mm	60 mm	Plastic pipe (without insulation) sealed with use of INTU FR GRAPHITE mass	100 mm
			Plastic pipe (without insulation) sealed with use of INTU FR COLLAR L SLIM collars (double-sided)	100 mm
			Metal pipe (without insulation) sealed with INTU FR UNICOAT P paint	100 mm
			Metal pipe with mineral wool insulation	100 mm
Metal pipe (without insulation) sealed with INTU FR UNICOAT P paint	100 mm	80 mm	Metal pipe (without insulation) sealed with INTU FR UNICOAT P paint	100 mm
			Plastic pipe (without insulation) sealed with use of INTU FR COLLAR L SLIM collars (double-sided)	100 mm
			Plastic pipe (without insulation) sealed with use of INTU FR GRAPHITE mass	100 mm
			Metal pipe with mineral wool insulation	100 mm
Metal pipe with mineral wool insulation	50 mm	30 mm	Metal pipe with mineral wool insulation	100 mm
			Plastic pipe (without insulation) sealed with use of INTU FR COLLAR L SLIM collars (double-sided)	100 mm
			Plastic pipe (without insulation) sealed with use of INTU FR GRAPHITE mass	100 mm
			Metal pipe (without insulation) sealed with INTU FR UNICOAT P paint	100 mm

- The services in the large penetration seal of cables with double INTU FR UNIBOARD 1S board or single INTU FR UNIBOARD 2S board in flexible or rigid wall and rigid floor are placed in the following distances (according to Figure A2):
 - a_1 – min. distance between the cable tray / ladder and long seal edge (top or bottom seal edge in case of walls): $a_1 = 0$ mm,
 - a_2 – min. distance between the cable trays / ladders: $a_2 = 0$ mm,
 - a_3 – min. distance between the cable tray / ladder and short seal edge (side seal edge in case of walls): $a_3 = 0$ mm,
 - a_4 – min. distance between the cable and top / short seal edge (top or bottom seal edge in case of walls): $a_4 = 0$ mm,
 - a_5 – min. distance between the cable (with or without cable carrier) and bottom edge of cable trays / ladders or between the cable without cable carrier and cable trays / ladders: $a_5 = 60$ mm.

INTU FR UNICOAT P, INTU FR UNIBOARD
Additional provisions (5)
Annex A
 of European
 Technical Assessment
 ETA-24/1047




Fig. A2. Example of large cable penetration seal

Table A5. Minimum distances between the services in cable penetration seals in wall or floor

Type of seal	Supporting construction	Distances				
		a ₁	a ₂	a ₃	a ₄	a ₅
INTU FR UNIBOARD 2S	Wall	0 mm	0 mm	0 mm	0 mm	60 mm
	Floor	0 mm	0 mm	0 mm	0 mm	60 mm
INTU FR UNIBOARD 1S	Wall	0 mm	0 mm	0 mm	0 mm	60 mm
	Floor	0 mm	0 mm	0 mm	0 mm	60 mm

- The minimum distances between the adjacent penetration seals made with use of INTU FR UNICOAT P, double INTU FR UNIBOARD 1S board or single INTU FR UNIBOARD 2S board in flexible or rigid wall and rigid floor is 100 mm.
- Services are placed in angle 90° to the supporting construction.
- Pipes shall be supported at maximum 400 mm away from both sides of the wall constructions and from the upper face of floor constructions.
- Cables shall be supported at maximum 400 mm away from the surface of separating element for first attachment, excluding cases where the cable support does not pass through the penetration seal, where the first support should be at a distance of maximum 150 mm.

INTU FR UNICOAT P, INTU FR UNIBOARD

Additional provisions (6)

Annex A
of European
Technical Assessment
ETA-24/1047

- Classifications given in Annex B are valid for plastic pipes:
 - PE-HD according to EN 1519-1 or EN 12666-1,
 - PE according to EN 12201-2, EN 1519-1, EN 12666-1 or EN ISO 15494,
 - PE-X according to EN ISO 15875-2,
 - ABS according to EN 1455-1 or EN ISO 15493,
 - SAN + PVC according to ISO 19220,
 - PP according to EN 1451-1, DIN 8077, DIN 8078, DIN 16962, EN 15874-2 or EN ISO 15494,
 - PVC-U according to EN 1329-1, EN 1453-1, EN ISO 1452-2 or EN ISO 15493,
 - PVC-C according to EN 1566-1, EN ISO 15493 or EN ISO 15877-2,
 - PP-R according to EN ISO 15874-2, DIN 8077 or DIN 8078,
 according to tables in Annex B.
- Classifications given in Annex B for copper and steel pipes are also valid for other metal pipe materials with:
 - thermal conductivity lower than respectively copper and galvanized steel, and
 - melting point at least equal to respectively copper and galvanized steel, and greater than:
 - 739°C for the fire resistance class EI 15 and E 15,
 - 781°C for the fire resistance class EI 20 and E 20,
 - 842°C for the fire resistance class EI 30 and E 30,
 - 902°C for the fire resistance class EI 45 and E 45,
 - 945°C for the fire resistance class EI 60 and E 60,
 - 1006°C for the fire resistance class EI 90 and E 90,
 - 1049°C for the fire resistance class EI 120 and E 120,
 - 1110°C for the fire resistance class EI 180 and E 180,
 - 1153°C for the fire resistance class EI 240 and E 240.
- Classifications given in Annex B for cables are valid for:
 - small cables that are currently and commonly used in building practice in Europe, with maximum diameter of 21 mm, including optical fibre cables, except tied bundles, waveguides and non-sheathed cables (wires),
 - medium cables that are currently and commonly used in building practice in Europe, with diameter greater than 21 mm and maximum diameter of 50 mm, including optical fibre cables and coaxial cables with maximum diameter of 28 mm, except tied bundles, waveguides and non-sheathed cables (wires),
 - large cables that are currently and commonly used in building practice in Europe, with diameter greater than 50 mm and maximum diameter of 80 mm, including optical fibre cables, except tied bundles, waveguides and non-sheathed cables (wires),
 - tied cable bundles with diameter of less than or equal to $\varnothing_{\text{bundle}}$ given in the appropriate point, made of cables commonly used in building practice in Europe to a maximum diameter of 21 mm, including optical fibre cables, except waveguides and non-sheathed cables (wires),
 according to tables in Annex B.

INTU FR UNICOAT P, INTU FR UNIBOARD

Additional provisions (7)

Annex A
of European
Technical Assessment
ETA-24/1047

- Classifications given in Annex B for cables sealed with INTU FR UNIBOARD 1S board or INTU FR UNIBOARD 2S board are valid for cables which can be placed on cable trays, ladders or brackets made of galvanized steel or other metal with melting point greater than:
 - 739°C for the fire resistance class 15 min,
 - 781°C for the fire resistance class 20 min,
 - 842°C for the fire resistance class 30 min,
 - 902°C for the fire resistance class 45 min,
 - 945°C for the fire resistance class 60 min,
 - 1006°C for the fire resistance class 90 min,
 - 1049°C for the fire resistance class 120 min.
 Where appropriate the cable carries should be discontinued on both sides of the penetration seal – not passing through the seal, according to Annex B and Annex C.
- Classifications given in Annex B for insulated pipes are valid for pipes with sustained and continued insulation made of Kaiflex ST flexible elastomeric foam (FEF) or Tubolit DG Plus (PE) insulation (for details see clause 1 of ETA) and does not cover locally insulated or non-insulated pipes. The thickness of insulation shall remain in accordance with ETA provisions.
- Classifications given in Annex B for metal pipes with Paroc Hvac Lamella Mat AluCoat mat local sustained mineral wool insulation concerns locally insulated pipes in case LS (local sustained) and does not cover locally insulated pipes in case LI (local interrupted) or non-insulated pipes. The length of insulation can be increased but may not be reduced. The thickness of insulation shall remain in accordance with ETA provisions.
- Classifications given in Annex B for metal pipes with Paroc Hvac Lamella Mat AluCoat mat local interrupted mineral wool insulation concerns locally insulated pipes in case LI (local interrupted) and does not cover locally insulated pipes in case LS (local sustained) or non-insulated pipes. The length of insulation can be increased but may not be reduced. The thickness of insulation shall remain in accordance with ETA provisions.

INTU FR UNICOAT P, INTU FR UNIBOARD	Annex A of European Technical Assessment ETA-24/1047
Additional provisions (8)	

Table B1. Resistance to fire classification of plastic pipes (without insulation) penetration seals in flexible or rigid wall thickness of: $t \geq 100$ mm, made with use of double-sided INTU FR COLLAR L SLIM and INTU FR UNIBOARD 1S, in accordance with Annex A and Fig. C1 in Annex C:

Pipe material	Pipe diameter [mm]	Pipe wall thickness [mm]	Number of collars x intumescent material width x thickness [mm]	Fire resistance class
PE-HD / PE / PE-X / ABS / SAN + PVC	$D \leq 75$	3,0 – 6,8	$2 \times 30,0 \times 4,0$	EI 120-U/C EI 120-C/C
	$75 < D \leq 90$	3,5 – 8,2	$2 \times 30,0 \times 8,0$	
	$90 < D \leq 110$	4,2 – 10,0	$2 \times 30,0 \times 10,0$	
PP	$D \leq 75$	1,9 – 12,5	$2 \times 30,0 \times 4,0$	EI 120-U/C EI 120-C/C
	$75 < D \leq 90$	2,2 – 15,0	$2 \times 30,0 \times 8,0$	
	$90 < D \leq 110$	2,7 – 18,3	$2 \times 30,0 \times 10,0$	
PP-R	$D \leq 20$	$\geq 2,3$	$2 \times 30,0 \times 4,0$	EI 120-U/C EI 120-C/C
	$20 < D \leq 25$	$\geq 2,7$	$2 \times 30,0 \times 4,0$	
	$25 < D \leq 32$	3,3 – 12,5	$2 \times 30,0 \times 4,0$	
	$32 < D \leq 40$	3,9 – 12,5	$2 \times 30,0 \times 4,0$	
	$40 < D \leq 50$	4,8 – 12,5	$2 \times 30,0 \times 4,0$	
	$50 < D \leq 63$	5,8 – 12,5	$2 \times 30,0 \times 4,0$	
	$63 < D \leq 75$	6,8 – 12,5	$2 \times 30,0 \times 4,0$	
	$75 < D \leq 90$	8,2 – 15,0	$2 \times 30,0 \times 8,0$	
	$90 < D \leq 110$	10,0 – 18,3	$2 \times 30,0 \times 10,0$	
PVC-U / PVC-C	$D \leq 75$	1,8 – 5,6	$2 \times 30,0 \times 4,0$	EI 120-U/C EI 120-C/C
	$75 < D \leq 90$	1,9 – 6,7	$2 \times 30,0 \times 8,0$	
	$90 < D \leq 110$	2,0 – 8,1	$2 \times 30,0 \times 10,0$	

INTU FR UNICOAT P, INTU FR UNIBOARD

Penetration seals made with use of INTU FR UNIBOARD 1S
Plastic pipes (without insulation) penetration seals in flexible or rigid wall

Annex B1
of European
Technical Assessment
ETA-24/1047

Table B2. Resistance to fire classification of plastic pipes with polyethylene foam (PE) continuous insulation (case CS), placed on the floor, penetration seals in flexible or rigid wall thickness of: $t \geq 100$ mm, made with use of double-sided INTU FR COLLAR L SLIM (U-shaped) and double INTU FR UNIBOARD 1S, in accordance with Annex A and Fig. C2a in Annex C:

Pipe material	Pipe diameter [mm]	Pipe wall thickness [mm]	Insulation thickness x length [mm]	Number of collars x intumescent material width x thickness [mm]	Fire resistance class
PP-R	$D \leq 20$	2,3	9	2 x 30,0 x 10,0	EI 120-U/C EI 120-C/C
		6,9	25	2 x 30,0 x 10,0	EI 120-U/C EI 120-C/C
		7,0 – 12,5	25	2 x 30,0 x 10,0	EI 90-U/C EI 90-C/C
	$20 < D \leq 50$	6,9	25	2 x 30,0 x 10,0	EI 120-U/C EI 120-C/C
		7,0 – 12,5	25	2 x 30,0 x 10,0	EI 90-U/C EI 90-C/C
	$50 < D \leq 75$	12,5	25	2 x 30,0 x 10,0	EI 90-U/C EI 90-C/C

INTU FR UNICOAT P, INTU FR UNIBOARD

Penetration seals made with use of INTU FR UNIBOARD 1S
Plastic pipes with insulation penetration seals in flexible or rigid wall

Annex B2
of European
Technical Assessment
ETA-24/1047

Table B3. Resistance to fire classification of PP-R pipes with polyethylene foam (PE) continuous insulation (case CS), placed on the floor, with following dimensions:

- pipe No. 1: diameter of: $D \leq 20$ mm, pipe wall thickness of: $t = 2,3$ mm, polyethylene foam (PE) insulation thickness of: 9 mm,
- pipe No. 2: diameter of: $D \leq 50$ mm, pipe wall thickness of: $t = 6,9$ mm, polyethylene foam (PE) insulation thickness of: 25 mm,

penetration seals in flexible or rigid wall thickness of: $t \geq 100$ mm, made with use of double-sided INTU FR COLLAR L SLIM (U-shaped) and INTU FR UNIBOARD 1S, in accordance with Annex A and Fig. C2b in Annex C:

Fire resistance class:

EI 120-U/C

EI 120-C/C

INTU FR UNICOAT P, INTU FR UNIBOARD

Penetration seals made with use of INTU FR UNIBOARD 2S
Plastic pipes (without insulation) penetration seals in flexible or rigid wall

Annex B3
of European
Technical Assessment
ETA-24/1047

Table B4. Resistance to fire classification of PE-HD / PE / PE-X / ABS / SAN + PVC pipes (without insulation) penetration seals in flexible or rigid wall thickness of: $t \geq 100$ mm, made with use of double-sided INTU FR COLLAR L SLIM and INTU FR UNIBOARD 2S, in accordance with Annex A and Fig. C3a, C3b and C3c in Annex C:

Pipe diameter [mm]	Pipe wall thickness [mm]	Number of collars x intumescent material width x thickness [mm]	Fire resistance class	Figure in Annex C
D ≤ 75	3,0 – 6,8	2 x 30,0 x 4,0	EI 60 / E 90-U/C EI 60 / E 90-C/C	Fig. C3c
75 < D ≤ 90	3,5 – 8,2	2 x 30,0 x 8,0		
90 < D ≤ 110	4,2 – 10,0	2 x 30,0 x 10,0		
D ≤ 75	3,0 – 6,8	2 x 30,0 x 4,0	EI 60 / E 90-U/C ¹⁾ EI 60 / E 90-C/C ¹⁾	Fig. C3a
75 < D ≤ 90	3,5 – 8,2	2 x 30,0 x 8,0		
90 < D ≤ 110	4,2 – 10,0	2 x 30,0 x 10,0		
D ≤ 75	3,0	2 x 30,0 x 4,0	EI 90 / E 120-U/C ²⁾ EI 90 / E 120-C/C ²⁾	Fig. C3b
	3,1 – 6,8	2 x 30,0 x 4,0	EI 60 / E 120-U/C ²⁾ EI 60 / E 120-C/C ²⁾	
75 < D ≤ 90	3,5 – 6,0	2 x 30,0 x 8,0	EI 90 / E 120-U/C ²⁾ EI 90 / E 120-C/C ²⁾	
	6,1 – 8,2	2 x 30,0 x 8,0	EI 60 / E 120-U/C ²⁾ EI 60 / E 120-C/C ²⁾	
90 < D ≤ 110	4,2 – 10,0	2 x 30,0 x 10,0	EI 90 / E 120-U/C ²⁾ EI 90 / E 120-C/C ²⁾	
			EI 90 / E 120-U/C ²⁾ EI 90 / E 120-C/C ²⁾	
¹⁾ valid only in case of fire acting from the INTU FR UNIBOARD 2S side				
²⁾ valid only in case of fire acting from the opposite side to the INTU FR UNIBOARD 2S				

INTU FR UNICOAT P, INTU FR UNIBOARD

Penetration seals made with use of INTU FR UNIBOARD 2S
Plastic pipes (without insulation) penetration seals in flexible or rigid wall

Annex B4
of European
Technical Assessment
ETA-24/1047

Table B5. Resistance to fire classification of plastic pipes (without insulation) penetration seals in rigid floor thickness of: $t \geq 150$ mm, made with use of one-sided INTU FR COLLAR L SLIM and INTU FR UNIBOARD 1S, in accordance with Annex A and Fig. C4a and C4b in Annex C:

Pipe material	Pipe diameter [mm]	Pipe wall thickness [mm]	Number of collars x intumescent material width x thickness [mm]	Fire resistance class	Figure in Annex C
PE-HD / PE / PE-X / ABS / SAN + PVC	$D \leq 75$	3,0 – 6,8	1 x 30,0 x 4,0	EI 120-U/C EI 120-C/C	Fig. C4a and C4b
	$75 < D \leq 90$	3,5 – 8,2	1 x 30,0 x 8,0		
	$90 < D \leq 110$	4,2 – 10,0	1 x 30,0 x 10,0		
	$110 < D \leq 125$	5,8 – 9,9	2 x 30,0 x 14,0		
	$125 < D \leq 160$	9,5	2 x 30,0 x 18,0		
PP	$D \leq 75$	1,9 – 12,5	1 x 30,0 x 4,0	EI 120-U/C EI 120-C/C	Fig. C4a and C4b
	$75 < D \leq 90$	2,2 – 15,0	1 x 30,0 x 8,0		
	$90 < D \leq 110$	2,7 – 18,3	1 x 30,0 x 10,0		
	$110 < D \leq 125$	3,1 – 14,0	2 x 30,0 x 14,0		
	$125 < D \leq 160$	3,9	2 x 30,0 x 18,0		
PP-R	$D \leq 20$	$\geq 2,3$	1 x 30,0 x 4,0	EI 120-U/C EI 120-C/C	Fig. C4a
	$20 < D \leq 25$	$\geq 2,7$	1 x 30,0 x 4,0		
	$25 < D \leq 32$	3,3 – 12,5	1 x 30,0 x 4,0		
	$32 < D \leq 40$	3,9 – 12,5	1 x 30,0 x 4,0		
	$40 < D \leq 50$	4,8 – 12,5	1 x 30,0 x 4,0		
	$50 < D \leq 63$	5,8 – 12,5	1 x 30,0 x 4,0		
	$63 < D \leq 75$	6,8 – 12,5	1 x 30,0 x 4,0		
	$75 < D \leq 90$	8,2 – 15,0	1 x 30,0 x 8,0		
PVC-U / PVC-C	$D \leq 75$	1,8 – 5,6	1 x 30,0 x 4,0	EI 120-U/C EI 120-C/C	Fig. C4a
	$75 < D \leq 90$	1,9 – 6,7	1 x 30,0 x 8,0		
	$90 < D \leq 110$	2,0 – 8,1	1 x 30,0 x 10,0		

INTU FR UNICOAT P, INTU FR UNIBOARD

Penetration seals made with use of INTU FR UNIBOARD 1S
Plastic pipes (without insulation) penetration seals in rigid floor

Annex B5
of European
Technical Assessment
ETA-24/1047

Table B6. Resistance to fire classification of PE-HD / PE / PE-X / ABS / SAN + PVC pipes (without insulation) penetration seals in rigid floor thickness of: $t \geq 150$ mm, made with use of one-sided INTU FR COLLAR L SLIM and INTU FR UNIBOARD 2S, in accordance with Annex A and Fig. C5a, C5b and C5c in Annex C:

Pipe diameter [mm]	Pipe wall thickness [mm]	Number of collars x intumescent material width x thickness [mm]	Fire resistance class	Figure in Annex C
$D \leq 75$	3,0 – 6,8	1 x 30,0 x 4,0	EI 90-U/C EI 90-C/C	Fig. C5a, C5b and C5c
$75 < D \leq 90$	3,5 – 8,2	1 x 30,0 x 8,0		
$90 < D \leq 110$	4,2 – 10,0	1 x 30,0 x 10,0		

INTU FR UNICOAT P, INTU FR UNIBOARD

Penetration seals made with use of INTU FR UNIBOARD 2S
Plastic pipes (without insulation) penetration seals in rigid floor

Annex B6
of European
Technical Assessment
ETA-24/1047

Table B7. Resistance to fire classification of plastic pipes (without insulation) penetration seals in flexible or rigid wall thickness of: $t \geq 100$ mm, made with double-sided INTU FR GRAPHITE mass and INTU FR UNIBOARD 1S, in accordance with Annex A and Fig. C6 in Annex C:

Pipe material	Pipe diameter [mm]	Pipe wall thickness [mm]	INTU FR GRAPHITE mass width x thickness [mm]	Fire resistance class
PP	$D \leq 75$	1,9 – 12,4	2 x 25,0 x 10,0 – 20,0	EI 45-U/C EI 45-C/C
		12,5 – 18,3	2 x 25,0 x 10,0 – 20,0	EI 90-U/C EI 90-C/C
	$75 < D \leq 90$	2,2 – 14,9	2 x 25,0 x 10,0 – 20,0	EI 45-U/C EI 45-C/C
		15,0 – 18,3	2 x 25,0 x 10,0 – 20,0	EI 90-U/C EI 90-C/C
	$90 < D \leq 110$	2,7 – 18,2	2 x 25,0 x 10,0 – 20,0	EI 45-U/C EI 45-C/C
		18,3	2 x 25,0 x 10,0 – 20,0	EI 90-U/C EI 90-C/C
PP-R	$D \leq 20$	$\geq 2,8$	2 x 25,0 x 10,0 – 20,0	EI 45-U/C EI 45-C/C
		$\geq 3,2$	2 x 25,0 x 10,0 – 20,0	
		$\geq 3,8$	2 x 25,0 x 10,0 – 20,0	
	$20 < D \leq 25$	$\geq 3,8$	2 x 25,0 x 10,0 – 20,0	EI 45-U/C EI 45-C/C
		$\geq 3,8$	2 x 25,0 x 10,0 – 20,0	
	$25 < D \leq 32$	$\geq 3,8$	2 x 25,0 x 10,0 – 20,0	EI 45-U/C EI 45-C/C
		$\geq 3,8$	2 x 25,0 x 10,0 – 20,0	
	$32 < D \leq 40$	4,4 – 18,2	2 x 25,0 x 10,0 – 20,0	EI 90-U/C EI 90-C/C
		18,3	2 x 25,0 x 10,0 – 20,0	
	$40 < D \leq 50$	5,2 – 18,2	2 x 25,0 x 10,0 – 20,0	EI 45-U/C EI 45-C/C
		18,3	2 x 25,0 x 10,0 – 20,0	
	$50 < D \leq 63$	6,2 – 18,2	2 x 25,0 x 10,0 – 20,0	EI 45-U/C EI 45-C/C
		18,3	2 x 25,0 x 10,0 – 20,0	
	$63 < D \leq 75$	7,2 – 18,2	2 x 25,0 x 10,0 – 20,0	EI 90-U/C EI 90-C/C
		18,3	2 x 25,0 x 10,0 – 20,0	
PVC-U / PVC-C	$D \leq 75$	8,4 – 18,2	2 x 25,0 x 10,0 – 20,0	EI 45-U/C EI 45-C/C
		18,3	2 x 25,0 x 10,0 – 20,0	
		18,3	2 x 25,0 x 10,0 – 20,0	
	$75 < D \leq 90$	10,0 – 18,2	2 x 25,0 x 10,0 – 20,0	EI 45-U/C EI 45-C/C
		18,3	2 x 25,0 x 10,0 – 20,0	
		18,3	2 x 25,0 x 10,0 – 20,0	
	$90 < D \leq 110$	10,0 – 18,2	2 x 25,0 x 10,0 – 20,0	EI 90-U/C EI 90-C/C
		18,3	2 x 25,0 x 10,0 – 20,0	
		18,3	2 x 25,0 x 10,0 – 20,0	
		18,3	2 x 25,0 x 10,0 – 20,0	

INTU FR UNICOAT P, INTU FR UNIBOARD

Penetration seals made with use of INTU FR UNIBOARD 1S
Plastic pipes (without insulation) penetration seals in flexible or rigid wall

Annex B7
of European
Technical Assessment
ETA-24/1047

Table B8. Resistance to fire classification of plastic pipes (without insulation) penetration seals in rigid floor thickness of: $t \geq 150$ mm, made with one-sided INTU FR GRAPHITE mass and INTU FR UNIBOARD 1S, in accordance with Annex A and Fig. C7 in Annex C:

Pipe material	Pipe diameter [mm]	Pipe wall thickness [mm]	INTU FR GRAPHITE mass depth x width [mm]	Fire resistance class
PP-R	$D \leq 20$	$\geq 2,3$	$1 \times 50,0 \times 10,0 - 20,0$	EI 90-U/C EI 90-C/C
	$20 < D \leq 25$	$\geq 2,7$	$1 \times 50,0 \times 10,0 - 20,0$	
	$25 < D \leq 32$	$3,3 - 12,5$	$1 \times 50,0 \times 10,0 - 20,0$	
	$32 < D \leq 40$	$3,9 - 12,5$	$1 \times 50,0 \times 10,0 - 20,0$	
	$40 < D \leq 50$	$4,8 - 12,5$	$1 \times 50,0 \times 10,0 - 20,0$	
	$50 < D \leq 63$	$5,8 - 12,5$	$1 \times 50,0 \times 10,0 - 20,0$	
	$63 < D \leq 75$	$6,8 - 12,5$	$1 \times 50,0 \times 10,0 - 20,0$	
	$75 < D \leq 90$	$8,2 - 15,0$	$1 \times 50,0 \times 10,0 - 20,0$	
	$90 < D \leq 110$	$10,0 - 18,3$	$1 \times 50,0 \times 10,0 - 20,0$	
PVC-U / PVC-C	$D \leq 75$	$1,5 - 8,1$	$1 \times 50,0 \times 10,0 - 20,0$	EI 90-U/C EI 90-C/C
	$75 < D \leq 90$	$1,7 - 8,1$	$1 \times 50,0 \times 10,0 - 20,0$	
	$90 < D \leq 110$	$2,0 - 8,1$	$1 \times 50,0 \times 10,0 - 20,0$	

INTU FR UNICOAT P, INTU FR UNIBOARD

Penetration seals made with use of INTU FR UNIBOARD 1S
Plastic pipes (without insulation) penetration seals in rigid floor

Annex B8
of European
Technical Assessment
ETA-24/1047

Table B9. Resistance to fire classification of metal pipes with mineral wool mat local sustained insulation (case LS) penetration seals in flexible or rigid wall thickness of: $t \geq 100$ mm, made with use of INTU FR UNIBOARD 1S, in accordance with Annex A and Fig. C8 in Annex C:

Pipe material	Pipe diameter [mm]	Pipe wall thickness [mm]	Mineral wool mat thickness g x length L_w [mm]	INTU FR UNIBOARD 1S number of layers x thickness [mm]	Fire resistance class
copper	$D \leq 28,0$	$\geq 1,0$	20 x 500	2 x 50 or 60	EI 120-C/U EI 120-C/C
	$28,0 < D \leq 33,7$	$\geq 1,1$	50 x 700	2 x 50 or 60	EI 90 / E 120-C/U EI 90 / E 120-C/C
	$33,7 < D \leq 42,4$	$\geq 1,2$	50 x 700	2 x 50 or 60	
	$42,4 < D \leq 54,0$	$\geq 1,4$	50 x 700	2 x 50 or 60	
	$54,0 < D \leq 66,7$	$\geq 1,6$	50 x 700	2 x 50 or 60	
	$66,7 < D \leq 76,1$	$\geq 1,8$	50 x 700	2 x 50 or 60	
	$76,1 < D \leq 88,9$	$\geq 2,0$	50 x 700	2 x 50 or 60	
steel	$D \leq 67,0$	1,5 – 3,9	30 x 500	2 x 50 or 60	EI 60 / E 120-C/U EI 60 / E 120-C/C
		$\geq 4,0$	50 x 700	2 x 50 or 60	EI 90 / E 120-C/U EI 90 / E 120-C/C
	$67,0 < D \leq 76,1$	1,6 – 3,9	50 x 700	2 x 50 or 60	EI 60 / E 120-C/U EI 60 / E 120-C/C
		$\geq 4,0$	50 x 700	2 x 50 or 60	EI 90 / E 120-C/U EI 90 / E 120-C/C
	$76,1 < D \leq 88,9$	1,8 – 3,9	50 x 700	2 x 50 or 60	EI 60 / E 120-C/U EI 60 / E 120-C/C
		$\geq 4,0$	50 x 700	2 x 50 or 60	EI 90 / E 120-C/U EI 90 / E 120-C/C
	$88,9 < D \leq 108,0$	2,0 – 3,9	50 x 700	2 x 50 or 60	EI 60 / E 120-C/U EI 60 / E 120-C/C
		$\geq 4,0$	50 x 700	2 x 50 or 60	EI 90 / E 120-C/U EI 90 / E 120-C/C
	$108,0 < D \leq 114,3$	2,1 – 3,9	50 x 700	2 x 50 or 60	EI 60 / E 120-C/U EI 60 / E 120-C/C
		$\geq 4,0$	50 x 700	2 x 50 or 60	EI 90 / E 120-C/U EI 90 / E 120-C/C
	$114,3 < D \leq 139,7$	2,6 – 3,9	50 x 700	2 x 50 or 60	EI 60 / E 120-C/U EI 60 / E 120-C/C
		$\geq 4,0$	50 x 700	2 x 50 or 60	EI 90 / E 120-C/U EI 90 / E 120-C/C
	$139,7 < D \leq 159,0$	2,9 – 3,9	50 x 700	2 x 50 or 60	EI 60 / E 120-C/U EI 60 / E 120-C/C
		$\geq 4,0$	50 x 700	2 x 50 or 60	EI 90 / E 120-C/U EI 90 / E 120-C/C
	$159,0 < D \leq 168,3$	3,1 – 3,9	50 x 700	2 x 50 or 60	EI 60 / E 120-C/U EI 60 / E 120-C/C
		$\geq 4,0$	50 x 700	2 x 50 or 60	EI 90 / E 120-C/U EI 90 / E 120-C/C
	$168,3 < D \leq 177,8$	3,3 – 3,9	50 x 700	2 x 50 or 60	EI 60 / E 120-C/U EI 60 / E 120-C/C
		$\geq 4,0$	50 x 700	2 x 50 or 60	EI 90 / E 120-C/U EI 90 / E 120-C/C
	$177,8 < D \leq 193,7$	3,5 – 3,9	50 x 700	2 x 50 or 60	EI 60 / E 120-C/U EI 60 / E 120-C/C
		$\geq 4,0$	50 x 700	2 x 50 or 60	EI 90 / E 120-C/U EI 90 / E 120-C/C
	$193,7 < D \leq 219,1$	$\geq 4,0$	50 x 700	2 x 50 or 60	EI 90 / E 120-C/U EI 90 / E 120-C/C

INTU FR UNICOAT P, INTU FR UNIBOARD

Penetration seals made with use of INTU FR UNIBOARD 1S
Metal pipes with insulation penetration seals in flexible or rigid wall

Annex B9
of European
Technical Assessment
ETA-24/1047

Table B10. Resistance to fire classification of steel pipes with mineral wool mat local sustained insulation (case LI) penetration seals in flexible or rigid wall thickness of: $t \geq 100$ mm, made with use of INTU FR UNIBOARD 1S, in accordance with Annex A and Fig. C9 in Annex C:

Pipe diameter [mm]	Pipe wall thickness [mm]	Mineral wool mat thickness g x length L_w [mm]	INTU FR UNIBOARD 1S number of layers x thickness [mm]	Fire resistance class
$D \leq 114,3$	$\geq 3,6$	50 x 500	2 x 50 or 60	EI 90-C/U EI 90-C/C

INTU FR UNICOAT P, INTU FR UNIBOARD

Penetration seals made with use of INTU FR UNIBOARD 1S
Metal pipes with insulation penetration seals in flexible or rigid wall

Annex B10
of European
Technical Assessment
ETA-24/1047

Table B11. Resistance to fire classification of metal pipes with mineral wool mat local sustained insulation (case LS) penetration seals in flexible or rigid wall thickness of: $t \geq 100$ mm, made with use of INTU FR UNIBOARD 2S, in accordance with Annex A and Fig. C10a, C10b and C10c in Annex C:

Pipe material	Pipe diameter [mm]	Pipe wall thickness [mm]	Mineral wool mat thickness g x length L_w [mm]	INTU FR UNIBOARD 2S number of layers x thickness [mm]	Fire resistance class	Figure in Annex C
copper	$D \leq 28,0$	$\geq 1,0$	20 x 500	1 x 50 or 60	EI 60 / E 90-C/U EI 60 / E 90-C/C	Fig. C10c
	$28,0 < D \leq 33,7$	$\geq 1,2$	30 x 500	1 x 50 or 60		
	$33,7 < D \leq 42,4$	$\geq 1,6$	30 x 500	1 x 50 or 60		
	$42,4 < D \leq 54,0$	$\geq 2,0$	30 x 500	1 x 50 or 60		
copper	$D \leq 28,0$	$\geq 1,0$	20 x 500	1 x 50 or 60	EI 60 / E 90-C/U ¹⁾ EI 60 / E 90-C/C ¹⁾	Fig. C10a
	$28,0 < D \leq 33,7$	$\geq 1,2$	30 x 500	1 x 50 or 60		
	$33,7 < D \leq 42,4$	$\geq 1,6$	30 x 500	1 x 50 or 60		
	$42,4 < D \leq 54,0$	$\geq 2,0$	30 x 500	1 x 50 or 60		
copper	$D \leq 28,0$	$\geq 1,0$	20 x 500	1 x 50 or 60	EI 60 / E 120-C/U ²⁾ EI 60 / E 120-C/C ²⁾	Fig. C10b
	$28,0 < D \leq 33,7$	$\geq 1,2$	30 x 500	1 x 50 or 60		
	$33,7 < D \leq 42,4$	$\geq 1,6$	30 x 500	1 x 50 or 60		
	$42,4 < D \leq 54,0$	$\geq 2,0$	30 x 500	1 x 50 or 60		
steel	$D \leq 67,0$	1,5 – 3,5	30 x 500	1 x 50 or 60	EI 60 / E 90-C/U EI 60 / E 90-C/C	Fig. C10c
		$\geq 3,6$	50 x 500	1 x 50 or 60	EI 60 / E 120-C/U EI 60 / E 120-C/C	
	$67,0 < D \leq 76,1$	1,9 – 3,5	50 x 500	1 x 50 or 60	EI 60 / E 90-C/U EI 60 / E 90-C/C	
		$\geq 3,6$	50 x 500	1 x 50 or 60	EI 60 / E 120-C/U EI 60 / E 120-C/C	
	$76,1 < D \leq 88,9$	2,5 – 3,5	50 x 500	1 x 50 or 60	EI 60 / E 90-C/U EI 60 / E 90-C/C	
		$\geq 3,6$	50 x 500	1 x 50 or 60	EI 60 / E 120-C/U EI 60 / E 120-C/C	
	$88,9 < D \leq 108,0$	3,3 – 3,5	50 x 500	1 x 50 or 60	EI 60 / E 90-C/U EI 60 / E 90-C/C	
		$\geq 3,6$	50 x 500	1 x 50 or 60	EI 60 / E 120-C/U EI 60 / E 120-C/C	
steel	$D \leq 67,0$	1,5 – 3,5	30 x 500	1 x 50 or 60	EI 60 / E 90-C/U ¹⁾ EI 60 / E 90-C/C ¹⁾	Fig. C10a
		$\geq 3,6$	30 x 500	1 x 50 or 60	EI 60 / E 120-C/U ¹⁾ EI 60 / E 120-C/C ¹⁾	
			50 x 500	1 x 50 or 60	EI 60 / E 120-C/U ¹⁾ EI 60 / E 120-C/C ¹⁾	
	$67,0 < D \leq 76,1$	1,9 – 3,5	50 x 500	1 x 50 or 60	EI 60 / E 90-C/U ¹⁾ EI 60 / E 90-C/C ¹⁾	
		$\geq 3,6$	50 x 500	1 x 50 or 60	EI 60 / E 120-C/U ¹⁾ EI 60 / E 120-C/C ¹⁾	
	$76,1 < D \leq 88,9$	2,5 – 3,5	50 x 500	1 x 50 or 60	EI 60 / E 90-C/U ¹⁾ EI 60 / E 90-C/C ¹⁾	
		$\geq 3,6$	50 x 500	1 x 50 or 60	EI 60 / E 120-C/U ¹⁾ EI 60 / E 120-C/C ¹⁾	
	$88,9 < D \leq 108,0$	3,3 – 3,5	50 x 500	1 x 50 or 60	EI 60 / E 90-C/U ¹⁾ EI 60 / E 90-C/C ¹⁾	
		$\geq 3,6$	50 x 500	1 x 50 or 60	EI 60 / E 120-C/U ¹⁾ EI 60 / E 120-C/C ¹⁾	
	$108,0 < D \leq 114,3$	$\geq 3,6$	50 x 500	1 x 50 or 60	EI 60 / E 120-C/U ¹⁾ EI 60 / E 120-C/C ¹⁾	
					EI 60 / E 120-C/U ¹⁾ EI 60 / E 120-C/C ¹⁾	

¹⁾ valid only in case of fire acting from the INTU FR UNIBOARD 2S side

²⁾ valid only in case of fire acting from the opposite side to the INTU FR UNIBOARD 2S

INTU FR UNICOAT P, INTU FR UNIBOARD

Penetration seals made with use of INTU FR UNIBOARD 2S
Metal pipes with insulation penetration seals in flexible or rigid wall

Annex B11
of European
Technical Assessment
ETA-24/1047

Table B11, cont. Resistance to fire classification of metal pipes with mineral wool mat local sustained insulation (case LS) penetration seals in flexible or rigid wall thickness of: $t \geq 100$ mm, made with use of INTU FR UNIBOARD 2S, in accordance with Annex A and Fig. C10a and C10b in Annex C:

Pipe material	Pipe diameter [mm]	Pipe wall thickness [mm]	Mineral wool mat thickness g x length L_w [mm]	INTU FR UNIBOARD 2S number of layers x thickness [mm]	Fire resistance class	Figure in Annex C
steel	$D \leq 67,0$	1,5 – 3,5	30 x 500	1 x 50 or 60	EI 60 / E 120-C/U ²⁾ EI 60 / E 120-C/C ²⁾	Fig. C10b
		$\geq 3,6$	30 x 500	1 x 50 or 60	EI 90 / E 120-C/U ²⁾ EI 90 / E 120-C/C ²⁾	
			50 x 500	1 x 50 or 60	EI 60 / E 120-C/U ²⁾ EI 60 / E 120-C/C ²⁾	
	$67,0 < D \leq 76,1$	1,9 – 3,5	50 x 500	1 x 50 or 60	EI 90 / E 120-C/U ²⁾ EI 90 / E 120-C/C ²⁾	
		$\geq 3,6$	50 x 500	1 x 50 or 60	EI 60 / E 120-C/U ²⁾ EI 60 / E 120-C/C ²⁾	
	$76,1 < D \leq 88,9$	2,5 – 3,5	50 x 500	1 x 50 or 60	EI 90 / E 120-C/U ²⁾ EI 90 / E 120-C/C ²⁾	
		$\geq 3,6$	50 x 500	1 x 50 or 60	EI 60 / E 120-C/U ²⁾ EI 60 / E 120-C/C ²⁾	
	$88,9 < D \leq 108,0$	3,3 – 3,5	50 x 500	1 x 50 or 60	EI 90 / E 120-C/U ²⁾ EI 90 / E 120-C/C ²⁾	
		$\geq 3,6$	50 x 500	1 x 50 or 60	EI 60 / E 120-C/U ²⁾ EI 60 / E 120-C/C ²⁾	
	$108,0 < D \leq 114,3$	$\geq 3,6$	50 x 500	1 x 50 or 60	EI 90 / E 120-C/U ²⁾ EI 90 / E 120-C/C ²⁾	
		$\geq 3,6$	50 x 500	1 x 50 or 60	EI 60 / E 120-C/U ²⁾ EI 60 / E 120-C/C ²⁾	
		$\geq 3,6$	50 x 500	1 x 50 or 60	EI 90 / E 120-C/U ²⁾ EI 90 / E 120-C/C ²⁾	

²⁾ valid only in case of fire acting from the opposite side to the INTU FR UNIBOARD 2S

INTU FR UNICOAT P, INTU FR UNIBOARD

Penetration seals made with use of INTU FR UNIBOARD 2S
Metal pipes with insulation penetration seals in flexible or rigid wall

Annex B12
of European
Technical Assessment
ETA-24/1047

Table B12. Resistance to fire classification of metal pipes with mineral wool mat local sustained insulation (case LS) penetration seals in rigid floor thickness of: $t \geq 150$ mm, made with use of INTU FR UNIBOARD 1S, in accordance with Annex A and Fig. C11 in Annex C:

Pipe material	Pipe diameter [mm]	Pipe wall thickness [mm]	Mineral wool mat thickness $g_w \times \text{length } L_w$ [mm]	INTU FR UNIBOARD 1S number of layers $\times$ thickness [mm]	Fire resistance class
copper	$D \leq 28,0$	$\geq 1,0$	20 x 500	2 x 50 or 60	EI 90 / E 120-C/U EI 90 / E 120-C/C
	$28,0 < D \leq 33,7$	$\geq 1,1$	50 x 700	2 x 50 or 60	
	$33,7 < D \leq 42,4$	$\geq 1,2$	50 x 700	2 x 50 or 60	
	$42,4 < D \leq 54,0$	$\geq 1,4$	50 x 700	2 x 50 or 60	
	$54,0 < D \leq 66,7$	$\geq 1,6$	50 x 700	2 x 50 or 60	
	$66,7 < D \leq 76,1$	$\geq 1,8$	50 x 700	2 x 50 or 60	
	$76,1 < D \leq 88,9$	$\geq 2,0$	50 x 700	2 x 50 or 60	
steel	$D \leq 67,0$	$\geq 1,5$	30 x 500	2 x 50 or 60	EI 120-C/U EI 120-C/C
	$67,0 < D \leq 76,1$	1,6 – 3,9	50 x 700	2 x 50 or 60	EI 90 / E 120-C/U EI 90 / E 120-C/C
		$\geq 4,0$	50 x 700	2 x 50 or 60	EI 120-C/U EI 120-C/C
	$76,1 < D \leq 88,9$	1,8 – 3,9	50 x 700	2 x 50 or 60	EI 90 / E 120-C/U EI 90 / E 120-C/C
		$\geq 4,0$	50 x 700	2 x 50 or 60	EI 120-C/U EI 120-C/C
	$88,9 < D \leq 108,0$	2,0 – 3,9	50 x 700	2 x 50 or 60	EI 90 / E 120-C/U EI 90 / E 120-C/C
		$\geq 4,0$	50 x 700	2 x 50 or 60	EI 120-C/U EI 120-C/C
	$108,0 < D \leq 114,3$	2,1 – 3,9	50 x 700	2 x 50 or 60	EI 90 / E 120-C/U EI 90 / E 120-C/C
		$\geq 4,0$	50 x 700	2 x 50 or 60	EI 120-C/U EI 120-C/C
	$114,3 < D \leq 139,7$	2,6 – 3,9	50 x 700	2 x 50 or 60	EI 90 / E 120-C/U EI 90 / E 120-C/C
		$\geq 4,0$	50 x 700	2 x 50 or 60	EI 120-C/U EI 120-C/C
	$139,7 < D \leq 159,0$	2,9 – 3,9	50 x 700	2 x 50 or 60	EI 90 / E 120-C/U EI 90 / E 120-C/C
		$\geq 4,0$	50 x 700	2 x 50 or 60	EI 120-C/U EI 120-C/C
	$159,0 < D \leq 168,3$	3,1 – 3,9	50 x 700	2 x 50 or 60	EI 90 / E 120-C/U EI 90 / E 120-C/C
		$\geq 4,0$	50 x 700	2 x 50 or 60	EI 120-C/U EI 120-C/C
	$168,3 < D \leq 177,8$	3,3 – 3,9	50 x 700	2 x 50 or 60	EI 90 / E 120-C/U EI 90 / E 120-C/C
		$\geq 4,0$	50 x 700	2 x 50 or 60	EI 120-C/U EI 120-C/C
	$177,8 < D \leq 193,7$	3,5 – 3,9	50 x 700	2 x 50 or 60	EI 90 / E 120-C/U EI 90 / E 120-C/C
		$\geq 4,0$	50 x 700	2 x 50 or 60	EI 120-C/U EI 120-C/C
	$193,7 < D \leq 219,1$	$\geq 4,0$	50 x 700	2 x 50 or 60	EI 120-C/U EI 120-C/C

INTU FR UNICOAT P, INTU FR UNIBOARD

Penetration seals made with use of INTU FR UNIBOARD 1S
Metal pipes with insulation penetration seals in rigid floor

Annex B13
of European
Technical Assessment
ETA-24/1047

Table B13. Resistance to fire classification of metal pipes with mineral wool mat local sustained insulation (case LS) penetration seals in rigid floor thickness of: $t \geq 150$ mm, made with use of INTU FR UNIBOARD 2S, in accordance with Annex A and Fig. C12a and C12b in Annex C:

Pipe material	Pipe diameter [mm]	Pipe wall thickness [mm]	Mineral wool mat thickness g _w x length L _w [mm]	INTU FR UNIBOARD 2S number of layers x thickness [mm]	Fire resistance class	Figure in Annex C
copper	D ≤ 28,0	≥ 1,0	20 x 500	1 x 50 or 60	EI 45 / E 90-C/U EI 45 / E 90-C/C	Fig. C12c
			30 x 500	1 x 50 or 60	EI 60 / E 90-C/U EI 60 / E 90-C/C	
	28,0 < D ≤ 33,7	≥ 1,2	30 x 500	1 x 50 or 60	EI 45 / E 90-C/U EI 45 / E 90-C/C	
	33,7 < D ≤ 42,4	≥ 1,6	30 x 500	1 x 50 or 60		
	42,4 < D ≤ 54,0	≥ 2,0	30 x 500	1 x 50 or 60		
copper	D ≤ 28,0	≥ 1,0	20 x 500	1 x 50 or 60	EI 45 / E 90-C/U ¹⁾ EI 45 / E 90-C/C ¹⁾	Fig. C12a
			30 x 500	1 x 50 or 60	EI 60 / E 90-C/U ¹⁾ EI 60 / E 90-C/C ¹⁾	
	28,0 < D ≤ 33,7	≥ 1,2	30 x 500	1 x 50 or 60	EI 45 / E 90-C/U ¹⁾ EI 45 / E 90-C/C ¹⁾	
	33,7 < D ≤ 42,4	≥ 1,6	30 x 500	1 x 50 or 60		
	42,4 < D ≤ 54,0	≥ 2,0	30 x 500	1 x 50 or 60		
copper	D ≤ 28,0	1,0 – 1,9	20 x 500	1 x 50 or 60	EI 45 / E 90-C/U ²⁾ EI 45 / E 90-C/C ²⁾	Fig. C12b
		≥ 2,0	20 x 500	1 x 50 or 60	EI 60 / E 120-C/U ²⁾ EI 60 / E 120-C/C ²⁾	
			30 x 500	1 x 50 or 60		
	28,0 < D ≤ 33,7	1,2 – 1,9	30 x 500	1 x 50 or 60	EI 45 / E 90-C/U ²⁾ EI 45 / E 90-C/C ²⁾	
		≥ 2,0	30 x 500	1 x 50 or 60	EI 60 / E 90-C/U ²⁾ EI 60 / E 90-C/C ²⁾	
	33,7 < D ≤ 42,4	1,6 – 1,9	30 x 500	1 x 50 or 60	EI 45 / E 90-C/U ²⁾ EI 45 / E 90-C/C ²⁾	
		≥ 2,0	30 x 500	1 x 50 or 60	EI 60 / E 90-C/U ²⁾ EI 60 / E 90-C/C ²⁾	
	42,4 < D ≤ 54,0	≥ 2,0	30 x 500	1 x 50 or 60	EI 60 / E 90-C/C ²⁾	
steel	D ≤ 67,0	1,5 – 3,5	30 x 500	1 x 50 or 60	EI 45 / E 90-C/U EI 45 / E 90-C/C	Fig. C12c
		≥ 3,6	30 x 500	1 x 50 or 60	EI 60 / E 90-C/U EI 60 / E 90-C/C	
			50 x 500	1 x 50 or 60		
	67,0 < D ≤ 76,1	1,9 – 3,5	50 x 500	1 x 50 or 60	EI 45 / E 90-C/U EI 45 / E 90-C/C	
		≥ 3,6	50 x 500	1 x 50 or 60	EI 60 / E 90-C/U EI 60 / E 90-C/C	
	76,1 < D ≤ 88,9	2,5 – 3,5	50 x 500	1 x 50 or 60	EI 45 / E 90-C/U EI 45 / E 90-C/C	
		≥ 3,6	50 x 500	1 x 50 or 60	EI 60 / E 90-C/U EI 60 / E 90-C/C	
	88,9 < D ≤ 108,0	3,3 – 3,5	50 x 500	1 x 50 or 60	EI 45 / E 90-C/U EI 45 / E 90-C/C	
		≥ 3,6	50 x 500	1 x 50 or 60	EI 60 / E 90-C/U EI 60 / E 90-C/C	
	108,0 < D ≤ 114,3	≥ 3,6	50 x 500	1 x 50 or 60	EI 60 / E 90-C/C	

¹⁾ valid only in case of INTU FR UNIBOARD 2S placed on bottom side of the floor

²⁾ valid only in case of INTU FR UNIBOARD 2S placed flush with top side of the floor

INTU FR UNICOAT P, INTU FR UNIBOARD

Penetration seals made with use of INTU FR UNIBOARD 2S
Metal pipes with insulation penetration seals in rigid floor

Annex B14
of European
Technical Assessment
ETA-24/1047

Table B13, cont. Resistance to fire classification of metal pipes with mineral wool mat local sustained insulation (case LS) penetration seals in rigid floor thickness of: $t \geq 150$ mm, made with use of INTU FR UNIBOARD 2S, in accordance with Annex A and Fig. C12a and C12b in Annex C:

Pipe material	Pipe diameter [mm]	Pipe wall thickness [mm]	Mineral wool mat thickness g_w x length L_w [mm]	INTU FR UNIBOARD 2S number of layers x thickness [mm]	Fire resistance class	Figure in Annex C
steel	D ≤ 67,0	≥ 1,5	30 x 500	1 x 50 or 60	EI 45 / E 90-C/U ¹⁾ EI 45 / E 90-C/C ¹⁾	Fig. C12a
			50 x 500	1 x 50 or 60	EI 60 / E 90-C/U ¹⁾ EI 60 / E 90-C/C ¹⁾	
	67,0 < D ≤ 76,1	≥ 1,9	50 x 500	1 x 50 or 60		
	76,1 < D ≤ 88,9	≥ 2,5	50 x 500	1 x 50 or 60		
	88,9 < D ≤ 108,0	≥ 3,3	50 x 500	1 x 50 or 60		
108,0 < D ≤ 114,3	≥ 3,6	50 x 500	1 x 50 or 60			
steel	D ≤ 67,0	1,5 – 3,5	30 x 500	1 x 50 or 60	EI 45 / E 90-C/U ²⁾ EI 45 / E 90-C/C ²⁾	Fig. C12b
		≥ 3,6	30 x 500	1 x 50 or 60	EI 60 / E 90-C/U ²⁾ EI 60 / E 90-C/C ²⁾	
			50 x 500	1 x 50 or 60		
	67,0 < D ≤ 76,1	1,9 – 3,5	50 x 500	1 x 50 or 60	EI 45 / E 90-C/U ²⁾ EI 45 / E 90-C/C ²⁾	
		≥ 3,6	50 x 500	1 x 50 or 60	EI 60 / E 90-C/U ²⁾ EI 60 / E 90-C/C ²⁾	
	76,1 < D ≤ 88,9	2,5 – 3,5	50 x 500	1 x 50 or 60	EI 45 / E 90-C/U ²⁾ EI 45 / E 90-C/C ²⁾	
		≥ 3,6	50 x 500	1 x 50 or 60	EI 60 / E 90-C/U ²⁾ EI 60 / E 90-C/C ²⁾	
	88,9 < D ≤ 108,0	3,3 – 3,5	50 x 500	1 x 50 or 60	EI 45 / E 90-C/U ²⁾ EI 45 / E 90-C/C ²⁾	
		≥ 3,6	50 x 500	1 x 50 or 60	EI 60 / E 90-C/U ²⁾ EI 60 / E 90-C/C ²⁾	
	108,0 < D ≤ 114,3	≥ 3,6	50 x 500	1 x 50 or 60	EI 60 / E 90-C/U ²⁾ EI 60 / E 90-C/C ²⁾	
		≥ 3,6	50 x 500	1 x 50 or 60	EI 60 / E 90-C/C ²⁾	
	1) valid only in case of INTU FR UNIBOARD 2S placed on bottom side of the floor					
2) valid only in case of INTU FR UNIBOARD 2S placed flush with top side of the floor						

INTU FR UNICOAT P, INTU FR UNIBOARD

Penetration seals made with use of INTU FR UNIBOARD 2S
Metal pipes with insulation penetration seals in rigid floor

Annex B15
of European
Technical Assessment
ETA-24/1047

Table B14. Resistance to fire classification of metal pipes (without insulation) penetration seals in flexible or rigid wall thickness of: $t \geq 100$ mm, made with use of double-sided INTU FR UNICOAT P and INTU FR UNIBOARD 1S, in accordance with Annex A and Fig. C13 in Annex C:

Pipe material	Pipe diameter [mm]	Pipe wall thickness [mm]	INTU FR UNIBOARD 1S number of layers x thickness [mm]	INTU FR UNICOAT P thickness x length L [mm]	Fire resistance class
galvanized steel	$D \leq 42,0$	$\geq 1,5$	2 x 50 lub 60	1,0 x 500	EI 60 / E 90-C/U EI 60 / E 90-C/C

INTU FR UNICOAT P, INTU FR UNIBOARD

Penetration seals made with use of INTU FR UNICOAT P
Metal pipes (without insulation) penetration seals in flexible or rigid wall

Annex B16
of European
Technical Assessment
ETA-24/1047

Table B15. Resistance to fire classification of metal pipes (without insulation) penetration seals in rigid floor thickness of: $t \geq 150$ mm, made with use of INTU FR UNICOAT P and INTU FR UNIBOARD 1S, in accordance with Annex A and Fig. C14 in Annex C:

Pipe material	Pipe diameter [mm]	Pipe wall thickness [mm]	INTU FR UNIBOARD 1S number of layers x thickness [mm]	INTU FR UNICOAT P thickness x length L_u [mm]	Fire resistance class
copper	$D \leq 28,0$	$\geq 1,0$	2 x 50 lub 60	1 x 500	EI 45 / E 120-C/U EI 45 / E 120-C/C
	$28,0 < D \leq 33,7$	$\geq 1,2$	2 x 50 lub 60	1 x 500	EI 30 / E 120-C/U EI 30 / E 120-C/C
	$33,7 < D \leq 42,4$	$\geq 1,6$	2 x 50 lub 60	1 x 500	
	$42,4 < D \leq 54,0$	$\geq 2,0$	2 x 50 lub 60	1 x 500	
galvanized steel	$D \leq 42,0$	$\geq 1,5$	2 x 50 lub 60	1 x 500	EI 90 / E 120-C/U EI 90 / E 120-C/C

INTU FR UNICOAT P, INTU FR UNIBOARD

Penetration seals made with use of INTU FR UNICOAT P
Metal pipes (without insulation) penetration seals in rigid floor

Annex B17
of European
Technical Assessment
ETA-24/1047

Table B16. Resistance to fire classification of metal pipes (without insulation) penetration seals in flexible or rigid wall thickness of: $t \geq 125$ mm, made with use of INTU FR UNICOAT P, in accordance with Annex A and Fig. C15 in Annex C:

Pipe material	Pipe diameter [mm]	Pipe wall thickness [mm]	INTU FR UNICOAT P thickness x length L [mm]	Fire resistance class
copper	$D \leq 54$	$\geq 2,0$	2,0 x 450,0	EI 45 / E 120-C/U EI 45 / E 120-C/c
galvanized steel	$D \leq 42$	$\geq 1,5$	1,0 x 450,0	EI 90 / E 120-C/U EI 90 / E 120-C/C
			2,0 x 450,0	EI 120-C/U EI 120-C/C

INTU FR UNICOAT P, INTU FR UNIBOARD

Penetration seals made with use of INTU FR UNICOAT P
Metal pipes (without insulation) penetration seals in rigid wall

Annex B18
of European
Technical Assessment
ETA-24/1047

Table B17. Resistance to fire classification of metal pipes (without insulation) penetration seals in rigid wall thickness of: $t \geq 100$ mm, made with use of INTU FR UNICOAT P, in accordance with Annex A and Fig. C16 in Annex C:

Pipe material	Pipe diameter [mm]	Pipe wall thickness [mm]	INTU FR UNICOAT P thickness x length L [mm]	Fire resistance class
copper	$D \leq 54$	$\geq 2,0$	$1,0 \times 500,0$	EI 120-C/U EI 120-C/C
galvanized steel	$D \leq 66,7$	$\geq 2,0$	$1,0 \times 500,0$	EI 60 / E 120-C/U EI 60 / E 120-C/C
	$66,7 < D \leq 76,1$	$\geq 2,3$	$1,0 \times 500,0$	
	$76,1 < D \leq 88,9$	$\geq 2,7$	$1,0 \times 500,0$	
	$88,9 < D \leq 108,0$	$\geq 3,4$	$1,0 \times 500,0$	
	$108,0 < D \leq 114,3$	$\geq 3,6$	$1,0 \times 500,0$	
	$114,3 < D \leq 139,7$	$\geq 3,8$	$1,0 \times 500,0$	
	$139,7 < D \leq 159,0$	$\geq 3,9$	$1,0 \times 500,0$	
	$159,0 < D \leq 168,3$	$\geq 4,0$	$1,0 \times 500,0$	

INTU FR UNICOAT P, INTU FR UNIBOARD

Penetration seals made with use of INTU FR UNICOAT P
Metal pipes (without insulation) penetration seals in rigid wall

Annex B19
of European
Technical Assessment
ETA-24/1047

Table B18. Resistance to fire classification of galvanized steel pipes (without insulation) penetration seals in rigid floor thickness of: $t \geq 150$ mm, made with use of INTU FR UNICOAT P, in accordance with Annex A and Fig. C17 and C20 in Annex C:

Pipe material	Pipe diameter [mm]	Pipe wall thickness [mm]	INTU FR UNICOAT P thickness x length L _u [mm]	Fire resistance class	Figure in Annex C
galvanized steel	D ≤ 42,0	≥ 1,5	1,0 x 500,0	EI 120-C/U EI 120-C/C	Fig. C17
	42,0 < D ≤ 54,0	≥ 1,8	1,0 x 500,0	EI 45 / E 120-C/U EI 45 / E 120-C/C	
	54,0 < D ≤ 66,7	≥ 2,2	1,0 x 500,0		
	66,7 < D ≤ 76,1	≥ 2,5	1,0 x 500,0		
	76,1 < D ≤ 88,9	≥ 2,9	1,0 x 500,0		
	88,9 < D ≤ 108,0	≥ 3,4	1,0 x 500,0		
	108,0 < D ≤ 114,3	≥ 3,6	1,0 x 500,0		
	114,3 < D ≤ 139,7	≥ 3,8	1,0 x 500,0		
	139,7 < D ≤ 159,0	≥ 3,9	1,0 x 500,0		
159,0 < D ≤ 168,3	≥ 4,0	1,0 x 500,0			
galvanized steel	D ≤ 88,9	≥ 1,5	1,0 x 500,0	EI 60 / E 120-C/U EI 60 / E 120-C/C	Fig. C20
	88,9 < D ≤ 108,0	≥ 3,4	1,0 x 500,0	EI 45 / E 120-C/U	
	108,0 < D ≤ 114,3	≥ 3,6	1,0 x 500,0	EI 45 / E 120-C/C	

INTU FR UNICOAT P, INTU FR UNIBOARD

Penetration seals made with use of INTU FR UNICOAT P
Metal pipes (without insulation) penetration seals in rigid floor

Annex B20
of European
Technical Assessment
ETA-24/1047

Table B19. Resistance to fire classification of metal pipes (without insulation) penetration seals in rigid wall thickness of: $t \geq 100$ mm, made with use of double-sided INTU FR UNICOAT P, in accordance with Annex A and Fig. C18 in Annex C:

Pipe material	Pipe diameter [mm]	Pipe wall thickness [mm]	INTU FR UNICOAT P thickness x length L [mm]	Fire resistance class
copper	$D \leq 28$	$\geq 1,0$	$1,0 \times 500,0$	EI 90 / E 120-C/U EI 90 / E 120-C/U
galvanized steel	$D \leq 42$	$\geq 1,5$	$1,0 \times 500,0$	EI 120-C/U EI 120-C/C

Table B20. Resistance to fire classification of galvanized steel pipes (without insulation) penetration seals in rigid wall thickness of: $t \geq 150$ mm, made with use of double-sided INTU FR UNICOAT P, in accordance with Annex A and Fig. C18 in Annex C:

Pipe material	Pipe diameter [mm]	Pipe wall thickness [mm]	INTU FR UNICOAT P thickness x length L [mm]	Fire resistance class
galvanized steel	$D \leq 42,0$	$\geq 1,5$	$1,0 \times 500,0$	EI 120-C/U EI 120-C/C
	$42,0 < D \leq 54,0$	$\geq 1,8$	$1,0 \times 500,0$	EI 45 / E 120-C/U EI 45 / E 120-C/C
	$54,0 < D \leq 66,7$	$\geq 2,2$	$1,0 \times 500,0$	
	$66,7 < D \leq 76,1$	$\geq 2,5$	$1,0 \times 500,0$	
	$76,1 < D \leq 88,9$	$\geq 2,9$	$1,0 \times 500,0$	
	$88,9 < D \leq 108,0$	$\geq 3,4$	$1,0 \times 500,0$	
	$108,0 < D \leq 114,3$	$\geq 3,6$	$1,0 \times 500,0$	

INTU FR UNICOAT P, INTU FR UNIBOARD

Penetration seals made with use of INTU FR UNICOAT P
Metal pipes (without insulation) penetration seals in rigid wall

Annex B21
of European
Technical Assessment
ETA-24/1047

Table B21. Resistance to fire classification of galvanized steel pipes with mineral wool mat local interrupted insulation (case LI) penetration seals in rigid wall thickness of: $t \geq 100$ mm, made with use of double-sided INTU FR UNICOAT P, in accordance with Annex A and Fig. C19 in Annex C:

Pipe material	Pipe diameter [mm]	Pipe wall thickness [mm]	Mineral wool mat thickness x length L_w [mm]	INTU FR UNICOAT P thickness x length L_u [mm]	Fire resistance class
galvanized steel	$D \leq 114,3$	$\geq 3,6$	20 x 200	1,0 x 500,0	EI 60 / E 120-C/U EI 60 / E 120-C/C
	$114,3 < D \leq 139,7$	$\geq 3,8$	20 x 200	2,0 x 500,0	EI 45 / E 120-C/U EI 45 / E 120-C/C
	$139,7 < D \leq 159,0$	$\geq 3,9$	20 x 200	2,0 x 500,0	
	$159,0 < D \leq 168,3$	$\geq 4,0$	20 x 200	2,0 x 500,0	

INTU FR UNICOAT P, INTU FR UNIBOARD

Penetration seals made with use of INTU FR UNICOAT P
Metal pipes with insulation penetration seals in rigid wall

Annex B22
of European
Technical Assessment
ETA-24/1047

Table B22. Resistance to fire classification of galvanized steel pipes with mineral wool mat local interrupted insulation (case LI) penetration seals in rigid floor thickness of: $t \geq 150$ mm, made with use of INTU FR UNICOAT P, in accordance with Annex A and Fig. C21 in Annex C:

Pipe material	Pipe diameter [mm]	Pipe wall thickness [mm]	Mineral wool mat thickness x length L_w [mm]	INTU FR UNICOAT P thickness x length L_u [mm]	Fire resistance class
galvanized steel	$D \leq 114,3$	$\geq 3,6$	20 x 200	1,0 x 500,0	EI 90 / E 120-C/U EI 90 / E 120-C/C
			20 x 350	1,0 x 500,0	EI 120-C/U EI 120-C/C
	$114,3 < D \leq 139,7$	$\geq 3,8$	20 x 200	2,0 x 500,0	EI 60 / E 120-C/U EI 60 / E 120-C/C
	$139,7 < D \leq 159,0$	$\geq 3,9$	20 x 200	2,0 x 500,0	
	$159,0 < D \leq 168,3$	$\geq 4,0$	20 x 200	2,0 x 500,0	

INTU FR UNICOAT P, INTU FR UNIBOARD

Penetration seals made with use of INTU FR UNICOAT P
Metal pipes with insulation penetration seals in rigid floor

Annex B23
of European
Technical Assessment
ETA-24/1047

Table B23. Resistance to fire classification of cable penetration seals in flexible or rigid wall thickness of: $t \geq 100$ mm, made with use of INTU FR UNICOAT P and double INTU FR UNIBOARD 1S, in accordance with Annex A and Fig. C22 in Annex C:

Type of cables	Cable diameter [mm]	INTU FR UNIBOARD 1S number of layers x thickness [mm]	INTU FR UNICOAT P thickness x length L [mm]	Fire resistance class
Small cables	$\varnothing \leq 21$	2 x 50 or 60	1,0 x 160,0	EI 90 / E 120
Medium cables	$21 < \varnothing \leq 50$	2 x 50 or 60	1,0 x 160,0	
Large cables	$50 < \varnothing \leq 80$	2 x 50 or 60	1,0 x 160,0	
Cable bundle	$\varnothing_{\text{cable}} \leq 21$ $\varnothing_{\text{bundle}} \leq 100$	2 x 50 or 60	1,0 x 160,0	
Non-sheathed cables (wires)	$\varnothing \leq 24$	2 x 50 or 60	1,0 x 160,0	
NYCWY 4x185/95 ¹⁾	according to HD 603.3G	2 x 50 or 60	1,0 x 160,0	
N2XH-J 4x185 ¹⁾	according to HD 604.5G	2 x 50 or 60	1,0 x 160,0	
Small cables	$\varnothing \leq 21$	2 x 50 or 60	1,0 x 160,0	EI 120 ²⁾
Cable bundle	$\varnothing_{\text{cable}} \leq 21$ $\varnothing_{\text{bundle}} \leq 100$	2 x 50 or 60	1,0 x 160,0	
Non-sheathed cables (wires)	$\varnothing \leq 24$	2 x 50 or 60	1,0 x 160,0	
NYCWY 4x185/95 ¹⁾	according to HD 603.3G	2 x 50 or 60	1,0 x 160,0	
N2XH-J 4x185 ¹⁾	according to HD 604.5G	2 x 50 or 60	1,0 x 160,0	
¹⁾ single cable penetration seal				
²⁾ valid only in case where the cable support does not pass through the penetration seal and / or in case where following cable carriers are passing through the seal: – perforated steel tray width of max. 500 mm and thickness of 1,5 mm, – non-perforated steel tray width of max. 500 mm and thickness of 1,5 mm, – steel ladder width of max. 200 mm and thickness of 1,0 mm, provided that the distance between adjacent cable trays / ladders in case of cable trays / ladders placed in one row is min 100 mm.				

INTU FR UNICOAT P, INTU FR UNIBOARD

Penetration seals made with use of INTU FR UNICOAT P and INTU UNIBOARD 1S

Cable penetration seals in flexible or rigid wall

Annex B24
of European
Technical Assessment
ETA-24/1047

Table B24. Resistance to fire classification of cable penetration seals in flexible or rigid wall thickness of: $t \geq 100$ mm, made with use of INTU FR UNICOAT P and single INTU FR UNIBOARD 2S, in accordance with Annex A and Fig. C23a, C23b and C23c in Annex C:

Type of cables	Cable diameter [mm]	INTU FR UNIBOARD 2S number of layers x thickness [mm]	INTU FR UNICOAT P thickness x length L [mm]	Fire resistance class	Figure in Annex C
Small cables	$\varnothing \leq 21$	1 x 50 or 60	1,0 x 200,0	EI 60	Fig. C23c
Medium cables	$21 < \varnothing \leq 50$	1 x 50 or 60	1,0 x 200,0		
Large cables	$50 < \varnothing \leq 80$	1 x 50 or 60	1,0 x 200,0		
Cable bundle	$\varnothing_{\text{cable}} \leq 21$ $\varnothing_{\text{bundle}} \leq 100$	1 x 50 or 60	1,0 x 200,0		
Non-sheathed cables (wires)	$\varnothing \leq 24$	1 x 50 or 60	1,0 x 200,0		
Rigid plastic conduits	$\varnothing \leq 16$	1 x 50 or 60	1,0 x 200,0	EI 60-U/U ¹⁾ EI 60-C/U ¹⁾ EI 60-U/C ¹⁾ EI 60-C/C ¹⁾	Fig. C23a
Small cables	$\varnothing \leq 21$	1 x 50 or 60	1,0 x 150,0	EI 60 / E 120 ²⁾	Fig. C23b
Medium cables	$21 < \varnothing \leq 50$	1 x 50 or 60	1,0 x 150,0		
Large cables	$50 < \varnothing \leq 80$	1 x 50 or 60	1,0 x 150,0		
Cable bundle	$\varnothing_{\text{cable}} \leq 21$ $\varnothing_{\text{bundle}} \leq 100$	1 x 50 or 60	1,0 x 150,0		
Non-sheathed cables (wires)	$\varnothing \leq 24$	1 x 50 or 60	1,0 x 150,0		
¹⁾ valid only in case of fire acting from the INTU FR UNIBOARD 2S side					
²⁾ valid only in case of fire acting from the opposite side to the INTU FR UNIBOARD 2S					

INTU FR UNICOAT P, INTU FR UNIBOARD

Penetration seals made with use of INTU FR UNICOAT P and INTU FR UNIBOARD 2S
Cable penetration seals in flexible or rigid wall

Annex B25
of European
Technical Assessment
ETA-24/1047

Table B25. Resistance to fire classification of cable penetration seals in rigid floor thickness of: $t \geq 150$ mm, made with use of INTU FR UNICOAT P and double INTU FR UNIBOARD 1S, in accordance with Annex A and Fig. C24 in Annex C:

Type of cables	Cable diameter [mm]	INTU FR UNIBOARD 1S number of layers x thickness [mm]	INTU FR UNICOAT P thickness x length L [mm]	Fire resistance class
Small cables	$\varnothing \leq 21$	2 x 50 or 60	1,0 x 160,0	EI 120
Medium cables	$21 < \varnothing \leq 50$	2 x 50 or 60	1,0 x 160,0	
Large cables	$50 < \varnothing \leq 80$	2 x 50 or 60	1,0 x 160,0	
Cable bundle	$\varnothing_{\text{cable}} \leq 21$ $\varnothing_{\text{bundle}} \leq 100$	2 x 50 or 60	1,0 x 160,0	
Non-sheathed cables (wires)	$\varnothing \leq 24$	2 x 50 or 60	1,0 x 160,0	

INTU FR UNICOAT P, INTU FR UNIBOARD

Penetration seals made with use of INTU FR UNICOAT P and INTU FR UNIBOARD 1S
Cable penetration seals in rigid floor

Annex B26
of European
Technical Assessment
ETA-24/1047

Table B26. Resistance to fire classification of cable penetration seals in rigid floor thickness of: $t \geq 150$ mm, made with use of INTU FR UNICOAT P and single INTU FR UNIBOARD 2S, in accordance with Annex A and Fig. C25 in Annex C:


Type of cables	Cable diameter [mm]	INTU FR UNIBOARD 2S number of layers x thickness [mm]	INTU FR UNICOAT P thickness x length L [mm]	Fire resistance class	Figure in Annex C
Small cables	$\varnothing \leq 21$	1 x 50 or 60	1,0 x 200,0	EI 60 / E 90	Fig. C25
Medium cables	$21 < \varnothing \leq 50$	1 x 50 or 60	1,0 x 200,0		
Large cables	$50 < \varnothing \leq 80$	1 x 50 or 60	1,0 x 200,0		
Cable bundle	$\varnothing_{\text{cable}} \leq 21$ $\varnothing_{\text{bundle}} \leq 100$	1 x 50 or 60	1,0 x 200,0		
Non-sheathed cables (wires)	$\varnothing \leq 24$	1 x 50 or 60	1,0 x 200,0		

INTU FR UNICOAT P, INTU FR UNIBOARD

Penetration seals made with use of INTU FR UNICOAT P and INTU FR UNIBOARD 2S
Cable penetration seals in rigid floor

Annex B27
of European
Technical Assessment
ETA-24/1047

Fig. C1. Plastic pipe (without insulation) penetration seals made with use of INTU FR COLLAR L SLIM collars (double-sided) in flexible or rigid wall



- 1 Flexible or rigid wall supporting construction thickness of: $A \geq 100$ mm
- 2 Double INTU FR UNIBOARD 1S board (2 x 50 mm or 2 x 60 mm)
- 3 Plastic pipe
- 4 Gap filled with INTU FR MASTIC – area between the pipe and INTU FR UNIBOARD 1S board, ring with max. width: $a = 20$ mm, on the minimum depth: $b = 25$ mm on both sides of the seal
- 5 Intumescent pipe collar roll INTU FR COLLAR L SLIM (double-sided – one collar on each side of the seal)
- 6 Steel Fire Spring fastener, length of 40 mm

INTU FR UNICOAT P, INTU FR UNIBOARD


Construction details

Plastic pipes (without insulation) penetration seals in flexible or rigid wall


Annex C1
of European
Technical Assessment
ETA-24/1047

Fig. C2. Plastic pipe with polyethylene foam (PE) insulation penetration seals made with use of INTU FR COLLAR L SLIM collars (double-sided) in flexible or rigid wall

a)



b)




- 1 Flexible or rigid wall supporting construction thickness of: $A \geq 100 \text{ mm}$
- 2 Plastic pipe with continuous polyethylene foam (PE) insulation
- 3 Double INTU FR UNIBOARD 1S board (2 x 50 mm or 2 x 60 mm)
- 4 Gap filled with INTU FR MASTIC – area between the pipe and INTU FR UNIBOARD 1S board, ring with max. width: $a = 20 \text{ mm}$, on the minimum depth: $b = 25 \text{ mm}$ on both sides of the seal
- 5 Intumescent pipe collar INTU FR COLLAR L SLIM (double-sided – one collar on each side of the seal)
- 6 Steel Fire Spring fastener, length of 40 mm
- 7 Rigid floor supporting construction

Note: S, L – short and long clips for fixing of collars

INTU FR UNICOAT P, INTU FR UNIBOARD		Annex C2 of European Technical Assessment ETA-24/1047
Construction details Plastic pipes with insulation penetration seals in flexible or rigid wall		

Fig. C3. Plastic pipe (without insulation) penetration seals made with use of INTU FR COLLAR L SLIM collars (double-sided) in flexible or rigid wall



- 1 Flexible or rigid wall supporting construction thickness of: $A \geq 100$ mm
- 2 Single INTU FR UNIBOARD 2S board (1 x 50 mm or 1 x 60 mm)
- 3 Plastic pipe
- 4 Gap filled with INTU FR MASTIC – area between the pipe and INTU FR UNIBOARD 2S board, ring with max. width: $a = 20$ mm, on the minimum depth: $b = 25$ mm on both sides of the seal
- 5 Intumescent pipe collar INTU FR COLLAR L SLIM (double-sided – one collar on each side of the seal)
- 6 Steel Fire Spring fastener, length of 40 mm


INTU FR UNICOAT P, INTU FR UNIBOARD

Construction details

Plastic pipes (without insulation) penetration seals in flexible or rigid wall

Annex C3
of European
Technical Assessment
ETA-24/1047

Fig. C4. Plastic pipe (without insulation) penetration seals made with use of INTU FR COLLAR L SLIM collars (one-sided) in rigid floor



- 1 Rigid floor supporting construction thickness of: $H \geq 150$ mm
- 2 Plastic pipe
- 3 Double INTU FR UNIBOARD 1S board (2 x 50 mm or 2 x 60 mm) flush with bottom and top floor surfaces
- 4 Gap filled with INTU FR MASTIC – area between the pipe and INTU FR UNIBOARD 1S board, ring with max. width: $a = 20$ mm, on the minimum depth: $b = 25$ mm on both sides of the seal
- 5 Intumescent pipe collar INTU FR COLLAR L SLIM (one-sided – single or double collar on the bottom side of the seal)
- 6 Steel Fire Spring fastener, length of 40 mm


INTU FR UNICOAT P, INTU FR UNIBOARD

Construction details

Plastic pipes (without insulation) penetration seals in rigid floor

Annex C4
of European
Technical Assessment
ETA-24/1047

Fig. C5. Plastic pipe (without insulation) penetration seals made with use of INTU FR COLLAR L SLIM collars (one-sided) in rigid floor



- 1 Rigid floor supporting construction thickness of: $H \geq 150$ mm
- 2 Plastic pipe
- 3 Single INTU FR UNIBOARD 2S board (1 x 50 mm or 1 x 60 mm)
- 4 Gap filled with INTU FR MASTIC – area between the pipe and INTU FR UNIBOARD 2S board, ring with max. width: $a = 20$ mm, on the minimum depth: $b = 25$ mm on both sides of the seal
- 5 Intumescent pipe collar INTU FR COLLAR L SLIM (one-sided – one collar on the bottom side of the seal)
- 6 Steel Fire Spring fastener, length of 40 mm


INTU FR UNICOAT P, INTU FR UNIBOARD

Construction details

Plastic pipes (without insulation) penetration seals in rigid floor

Annex C5
of European
Technical Assessment
ETA-24/1047

Fig. C6. Plastic pipe (without insulation) penetration seals made with use of INTU FR GRAPHITE mass in flexible or rigid wall



- 1 Flexible or rigid wall supporting construction thickness of: $A \geq 100 \text{ mm}$
- 2 Double INTU FR UNIBOARD 1S board (2 x 50 mm or 2 x 60 mm)
- 3 Plastic pipe
- 4 Gap filled with INTU FR GRAPHITE sealant – area between the pipe and INTU FR UNIBOARD 1S board, ring with width: $a = 10 \text{ to } 20 \text{ mm}$, on the minimum depth: $b = 25 \text{ mm}$ on both sides of the seal


INTU FR UNICOAT P, INTU FR UNIBOARD

Construction details

Plastic pipes (without insulation) penetration seals in flexible or rigid wall

Annex C6
of European
Technical Assessment
ETA-24/1047

Fig. C7. Plastic pipe (without insulation) penetration seals made with use of INTU FR GRAPHITE mass in rigid floor



- 1 Rigid floor supporting construction thickness of: $H \geq 150$ mm
- 2 Plastic pipe
- 3 Double INTU FR UNIBOARD 1S board (2 x 50 mm or 2 x 60 mm) flush with bottom and top floor surfaces
- 4 Gap filled with INTU FR GRAPHITE sealant – area between the pipe and bottom INTU FR UNIBOARD 1S board, ring with width: $a = 10$ to 20 mm, on the whole depth of the bottom mineral wool board $b = 50$ mm


INTU FR UNICOAT P, INTU FR UNIBOARD

Construction details

Plastic pipes (without insulation penetration) seals in rigid floor

Annex C7
of European
Technical Assessment
ETA-24/1047

Fig. C8. Metal pipe with mineral wool insulation in flexible or rigid wall



- 1 Flexible or rigid wall supporting construction thickness of: $A \geq 100 \text{ mm}$
- 2 Metal pipe with local sustained insulation (case LS) made of mineral wool mat with length L_w and thickness g , according to table B9
- 3 Double INTU FR UNIBOARD 1S board (2 x 50 mm or 2 x 60 mm)


INTU FR UNICOAT P, INTU FR UNIBOARD

Construction details

Metal pipes with insulation penetration seals in flexible or rigid wall

Annex C8
of European
Technical Assessment
ETA-24/1047

Fig. C9. Metal pipe with mineral wool insulation in flexible or rigid wall



- 1 Flexible or rigid wall supporting construction thickness of: $A \geq 100 \text{ mm}$
- 2 Metal pipe
- 3 Double INTU FR UNIBOARD 1S board (2 x 50 mm or 2 x 60 mm)
- 4 Local interrupted insulation (case LI) made of mineral wool mat with length L_w and thickness g , according to table B10

INTU FR UNICOAT P, INTU FR UNIBOARD


Construction details

Metal pipes with insulation penetration seals in flexible or rigid wall


Annex C9
of European
Technical Assessment
ETA-24/1047

Fig. C10. Metal pipe with mineral wool insulation penetration seals in flexible or rigid wall


a)



b)



c)




- 1 Flexible or rigid wall supporting construction thickness of: $A \geq 100$ mm
- 2 Metal pipe, with local sustained insulation (case LS) made of mineral wool mat with length L_w and thickness g , according to table B11
- 3 Single INTU FR UNIBOARD 2S board (1 x 50 mm or 1 x 60 mm)

INTU FR UNICOAT P, INTU FR UNIBOARD
Construction details

Metal pipes with insulation penetration seals in flexible or rigid wall

Annex C10
 of European
 Technical Assessment
 ETA-24/1047

Fig. C11. Metal pipe with mineral wool insulation in rigid floor




- 1 Rigid floor supporting construction thickness of: $H \geq 150 \text{ mm}$
- 2 Metal pipe with local sustained insulation (case LS) made of mineral wool mat with length L_w and thickness g_w , according to table B12
- 3 Double INTU FR UNIBOARD 1S board (2 x 50 mm or 2 x 60 mm)

INTU FR UNICOAT P, INTU FR UNIBOARD

Construction details
Metal pipes with insulation penetration seals in rigid floor

Annex C11
of European
Technical Assessment
ETA-24/1047

Fig. C12. Metal pipe with mineral wool insulation penetration seals in rigid floor



- 1 Rigid floor supporting construction thickness of: $H \geq 150$ mm
- 2 Metal pipe with local sustained insulation (case LS) made of mineral wool mat with length L_w and thickness g_w , according to table B13
- 3 Single INTU FR UNIBOARD 2S board (1 x 50 mm or 1 x 60 mm)

INTU FR UNICOAT P, INTU FR UNIBOARD

Construction details
Metal pipes with insulation penetration seals in rigid floor

Annex C12
of European
Technical Assessment
ETA-24/1047

Fig. C13. Metal pipe (without insulation) penetration seals made with use of INTU FR UNICOAT P paint in flexible or rigid wall



- 1 Flexible or rigid wall supporting construction thickness of: $A \geq 100$ mm
- 2 Metal pipe
- 3 Double INTU FR UNIBOARD 1S board (2 x 50 mm or 2 x 60 mm)
- 4 INTU FR UNICOAT P paint with length L according to table B14


INTU FR UNICOAT P, INTU FR UNIBOARD

Construction details

Metal pipes (without insulation) penetration seals in flexible or rigid wall

Annex C13
of European
Technical Assessment
ETA-24/1047

Fig. C14. Metal pipe (without insulation) penetration seals made with use of INTU FR UNICOAT P paint in rigid floor



- 1 Rigid floor supporting construction thickness of: $H \geq 150 \text{ mm}$
- 2 Metal pipe
- 3 Double INTU FR UNIBOARD 1S board (2 x 50 mm or 2 x 60 mm)
- 4 INTU FR UNICOAT P paint with length L_u according to table B15


INTU FR UNICOAT P, INTU FR UNIBOARD

Construction details

Metal pipes (without insulation) penetration seals in rigid floor

Annex C14
of European
Technical Assessment
ETA-24/1047

Fig. C15. Metal pipe (without insulation) penetration seals made with use of INTU FR UNICOAT P paint in flexible or rigid wall



- 1 Flexible or rigid wall supporting construction thickness of: $A \geq 125 \text{ mm}$
- 2 Metal pipe
- 3 Gap filled with INTU FR MASTIC – area between the pipe and supporting construction ring with max. width: $a = 25 \text{ mm}$, on the minimum depth: $b = 25 \text{ mm}$ on both sides of the wall
- 4 INTU FR UNICOAT P paint on both sides of the wall: length L according to table B16


INTU FR UNICOAT P, INTU FR UNIBOARD

Construction details

Metal pipes (without insulation) penetration seals in flexible or rigid wall

Annex C15
of European
Technical Assessment
ETA-24/1047

Fig. C16. Metal pipe (without insulation) penetration seals made with use of INTU FR UNICOAT P paint in rigid wall



- 1 Rigid wall supporting construction thickness of: $A \geq 100$ mm
- 2 Gap filled with INTU FR MASTIC – area between the pipe and supporting construction ring with max. width: $a = 30$ mm, on the minimum depth: $b = 15$ mm on both sides of the wall
- 3 Backfill material – rock mineral wool with density of min. 35 kg/m^3 and reaction to fire class A1 according to EN 13501-1, depth of 15 mm
- 4 Metal pipe
- 5 INTU FR UNICOAT P paint on both sides of the wall: length L according to table B17


INTU FR UNICOAT P, INTU FR UNIBOARD

Construction details

Metal pipes (without insulation) penetration seals in rigid wall

Annex C16
of European
Technical Assessment
ETA-24/1047

Fig. C17. Metal pipe (without insulation) penetration seals made with use of INTU FR UNICOAT P paint in rigid floor



- 1 Rigid floor supporting construction thickness of: $H \geq 150$ mm
- 2 Metal pipe
- 3 Gap filled with INTU FR MASTIC – area between the pipe and supporting construction ring with max. width: $a = 20$ mm, on the minimum depth: $b = 25$ mm on both sides of the floor
- 4 Backfill material – rock mineral wool with density of min. 35 kg/m^3 and reaction to fire class A1 according to EN 13501-1, depth of 25 mm
- 5 INTU FR UNICOAT P paint on both sides of the floor with length L_u according to table B18


INTU FR UNICOAT P, INTU FR UNIBOARD

Construction details

Metal pipes without insulation penetration seals in rigid floor

Annex C17
of European
Technical Assessment
ETA-24/1047

Fig. C18. Metal pipe (without insulation) penetration seals made with use of INTU FR UNICOAT P paint in rigid wall



- 1 Rigid wall supporting construction thickness of: $A \geq 100 \text{ mm}$
- 2 Gap filled with cement mortar – area between the pipe and supporting construction ring with max. width: $a = 30 \text{ mm}$, on the whole depth of the wall
- 3 Metal pipe
- 4 INTU FR UNICOAT P paint on both sides of the wall with length L according to tables B19 and B20


INTU FR UNICOAT P, INTU FR UNIBOARD

Construction details

Metal pipes without insulation penetration seals in rigid wall

Annex C18
of European
Technical Assessment
ETA-24/1047

Fig. C19. Metal pipe with mineral wool insulation penetration seals made with use of INTU FR UNICOAT P paint in rigid wall




- 1 Rigid wall supporting construction thickness of: $A \geq 100 \text{ mm}$
- 2 Metal pipe
- 3 Gap filled with cement mortar – area between the pipe and supporting construction ring with max. width: $a = 30 \text{ mm}$, on the whole depth of the wall
- 4 Local interrupted insulation – mineral wool mat with thickness $g = 20 \text{ mm}$ and length L_w according to table B21
- 5 INTU FR UNICOAT P paint on both sides of the wall with length L_u according to table B21

INTU FR UNICOAT P, INTU FR UNIBOARD

Construction details
Metal pipes with insulation penetration seals in rigid wall

Annex C19
of European
Technical Assessment
ETA-24/1047

Fig. C20. Metal pipe (without insulation) penetration seals made with use of INTU FR UNICOAT P paint in rigid floor



- 1 Rigid floor supporting construction thickness of: $H \geq 150$ mm
- 2 Metal pipe
- 3 Gap filled with cement mortar – area between the pipe and supporting construction ring with max. width: $a = 30$ mm, on the whole depth of the floor
- 4 INTU FR UNICOAT P paint on both sides of the floor with length L_u according to table B18


INTU FR UNICOAT P, INTU FR UNIBOARD

Construction details

Metal pipes without insulation penetration seals in rigid floor

Annex C20
of European
Technical Assessment
ETA-24/1047

Fig. C21. Metal pipe with mineral wool insulation penetration seals made with use of INTU FR UNICOAT P paint in rigid floor




- 1 Rigid floor supporting construction thickness of: $H \geq 150$ mm
- 2 Metal pipe
- 3 Gap filled with cement mortar – area between the pipe and supporting construction ring with max. width: $a = 30$ mm, on the whole depth of the floor
- 4 Local interrupted insulation – mineral wool mat with thickness $g_w = 20$ mm and length L_w according to table B22
- 5 INTU FR UNICOAT P paint on both sides of the floor with length L_u according to table B22

INTU FR UNICOAT P, INTU FR UNIBOARD

Construction details
Metal pipes with insulation penetration seals in rigid floor

Annex C21
of European
Technical Assessment
ETA-24/1047

Fig. C22. Cable penetration seals made with use of INTU FR UNICOAT P paint in flexible or rigid wall




- 1 Flexible or rigid wall supporting construction thickness of: $A \geq 100 \text{ mm}$
- 2 Cable, bundle of cables, cable tray / ladder
- 3 Double INTU FR UNIBOARD 1S board (2 x 50 mm or 2 x 60 mm)
- 4 INTU FR UNICOAT P paint: length L according to table B23

INTU FR UNICOAT P, INTU FR UNIBOARD

Construction details
Cable penetration seals in flexible or rigid wall

Annex C22
of European
Technical Assessment
ETA-24/1047

Fig. C23. Cable penetration seals made with use of INTU FR UNICOAT P paint in flexible or rigid wall




- 1 Flexible or rigid wall supporting construction thickness of: $A \geq 100 \text{ mm}$
- 2 Cable, bundle of cables, cable tray / ladder
- 3 Single INTU FR UNIBOARD 2S board ($1 \times 50 \text{ mm}$ or $1 \times 60 \text{ mm}$)
- 4 INTU FR UNICOAT P paint: length L according to table B24

INTU FR UNICOAT P, INTU FR UNIBOARD

Construction details
Cable penetration seals in flexible or rigid wall

Annex C23
of European
Technical Assessment
ETA-24/1047

Fig. C24. Cable penetration seals made with use of INTU FR UNICOAT P paint in rigid floor




- 1 Rigid floor supporting construction thickness of: $H \geq 150 \text{ mm}$
- 2 INTU FR UNICOAT P paint: length L according to table B25
- 3 Double INTU FR UNIBOARD 1S board (2 x 50 mm or 2 x 60 mm) flush with bottom and top floor surfaces
- 4 Cable, bundle of cables, cable tray / ladder

INTU FR UNICOAT P, INTU FR UNIBOARD

Construction details
Cable penetration seals in rigid floor

Annex C24
of European
Technical Assessment
ETA-24/1047

Fig. C25. Cable penetration seals made with use of INTU FR UNICOAT P paint in rigid floor



- 1 Rigid floor supporting construction thickness of: $H \geq 150 \text{ mm}$
- 2 INTU FR UNICOAT P paint: length L according to table B26
- 3 Single INTU FR UNIBOARD 2S board (1 x 50 mm or 1 x 60 mm), covered by INTU FR UNICOAT P paint, dry layer thickness of 0,5 mm
- 4 Cable, bundle of cables, cable tray / ladder

INTU FR UNICOAT P, INTU FR UNIBOARD

Construction details
Cable penetration seals in rigid floor

Annex C25
of European
Technical Assessment
ETA-24/1047